

power supply circuit. Necessary float and boost charger shall be incorporated in the control section of power and control panel with manual selection of boost charge, to keep the battery under trim condition. Voltmeter to indicate the state of charge of the batteries shall be provided. Where separate batteries are provided for automatic and manual starting, the charging equipment shall be capable of trickle charging both the batteries simultaneously. Equipment shall be provided to enable the state of charge of the batteries to be determined.

6.4.16 The engine installation shall be approved by the representative of engine manufacturer (who shall carry out after sales service under AMC).

6.4.17 The following spare parts shall be supplied with the engine and kept on hand:

- a) Two sets of fuel filters, elements and seals;
- b) Two sets of lubricating oil filters, elements and seals;
- c) Two sets of belts(where used);
- d) One complete set of engine-joints, gaskets and hoses;
- e) Two injector nozzles;
- f) One complete set of piston rings for each cylinder; and
- g) One inlet valve and one exhaust valve).

7. PIPE WORK

7.1 SCOPE

This chapter covers the requirements of pipe work in firefighting installations.

7.2 PLUMBING DESIGN

Pipe sizes shown in tender documents are purely for contractor's guidance. The contractor shall be responsible for selection of sizes as per detailed engineering to be done by him. Plumbing design to be done by the contractor shall incorporate the following: -

- (i) (a) Sluice valves shall be provided at suction and delivery sides of pumps.
 - (b) External hydrant
 - (c) Fire service connection/inlet.
 - (d) Test valve.
 - (e) Drain connections.
- (ii) For testing the system healthiness and automatic operation on daily basis, one test pipe with sluice valve shall be provided in common discharge header. For avoiding wastage of water, this pipe shall discharge water in the tank.
- (iii) Non-return valve shall be provided at the delivery of each pump and fire service inlet. This shall be of swing type.
- (iv) Air release valves with ball valve shall be provided in the piping system for venting trapped air with a size of 25 mm for pipes up to 100 mm and 40 mm for larger pipes.
- (v) Plumbing drawings showing the sizes of pipe, valves, layout and other details shall be prepared and shall be got approved from the Engineer-in-Charge before the execution of the plumbing work.

7.3 PIPE MATERIALS

Pipes shall be of the following materials:

- (a) Mild steel heavy class (C-class) conforming to IS:1239 for sizes up to 150 mm.

- (b) Welded black steel pipe, Class 2, conforming to IS: 3589, for sizes greater than 150 mm. These pipes shall be factory rolled and fabricated from minimum 6mm thick M.S. Sheet for pipes upto 350 mm diameter and from minimum 7 mm thick M.S. sheet for pipes of 400 mm diameter and above.
MS pipes may be allowed for extension of existing systems which are laid with CI pipes.
- (c) Cast iron double flanged pipe, Class-A conforming to IS 1536 or IS: 1537 (to be provided only in underground application).
Note: For pipe work of Automatic Sprinkler System inside the building, Stainless Steel Pipes and fittings of grade AISI 304 as per JIS standard 3448 are also permitted particularly where replacement of pipes is not easy like areas above false ceiling etc., subject to the condition that these pipes with associated fittings are suitable to safely withstand the system test pressures.
- (d) (i) GI Pipe medium Class (B-class) conforming to IS:1239 (For Drain)
(ii) Cadmium plated steel nuts/bolts/washers shall be used.
(iii) Flex drop of stainless steel metallic pipe with mounting accessories, frame for installation on false ceiling.

7.4 PIPE JOINTS

- i) Electric welding joints shall be provided in the MS pipe work. Flanged joints shall be provided for connections to valves, pumps, air vessels etc. and also on straight lengths at suitable points to facilitate erection and subsequent maintenance.
- ii) For connection of C.I. Pipe, fittings shall also be of C. I. heavy grade conforming to IS:1538. The flanges shall be smooth faced and neoprene gasket shall be provided between joints. All bolt holes in flanges shall be drilled. The drilling of each flange shall be in accordance with the relevant Indian Standards. Where un-avoidable and to connect underground pipe with risers, MS pipe may be used in the form of distant pieces. The joint between C.I. and MS pipe shall be flanged type. MS pipe laid at such locations shall be provided anti-corrosive treatment as per Para 7.5.
- iii) Mild steel flanges shall be in accordance with Table - 17 of IS : 6392 i.e. "Plate Flanges for Welding" and flange thickness shall be as under. Gasket thickness shall not be less than 3 mm.

Pipe diameter	Flange Thickness
200 mm	24 mm
150 mm and 125 mm	22 mm
100 mm and 80 mm	20 mm
65 mm	18 mm
40 mm and below	16 mm

- iv) Fittings installed underground shall be of cast iron 'heavy' grade conforming to IS 1538 whereas those installed above ground shall normally be of medium grade wrought steel or mild steel conforming to IS 1239 (Part 2) or malleable iron fittings conforming to IS 1879.
- v) All hardware items such as Nuts, Bolts, Washers shall be of appropriate size. Washers shall be used on both sides of the bolt.

7.5 ANTI-CORROSIVE PROTECTION ON UNDER GROUND MS PIPE

Corrosion protection tape shall be wrapped on MS pipes to be buried in ground. This corrosion protection tape shall comprise of coal tar/asphalt component supported on fabric of organic or inorganic fibre and minimum 4 mm thick and conform to requirement of IS :

10221-Code of practice for coating and wrapping of underground mild steel pipe line. Before application of corrosion protection tape all foreign matter on pipe shall be removed with the help of wire brush and suitable primer shall be applied over the pipe thereafter. The primer shall be allowed to dry until the solvent evaporates and the surface becomes tacky. Both primer and tape shall be furnished by the same manufacturer. Corrosion protection tape shall then be wound around the pipe in spiral fashion and bounded completely to the pipe. There shall be no air pocket or bubble beneath the tape. The overlaps shall be 15 mm and 250 mm shall be left uncoated on either end of pipe to permit installation and welding. This area shall be coated in situ after the pipe line is installed. The tapes shall be wrapped in accordance with the manufacturer's recommendations. If application is done in cold weather, the surface of the pipe shall be pre-heated until it is warm to touch and traces of moisture are removed and then primer shall be applied and allowed to dry.

Holiday Testing for wrapping and coating is essential. Holiday testing may preferably be carried by flexible and detachable ring probe, which will enable the entire 360° of the surface of the pipe to be scanned.

At least 10 percent of all the welded joints shall be radio graphically tested and half of the joints radio graphed shall be the 'field joints'.

7.6 VALVES

Each pump shall be provided with a non-return valve and a sluice valve on the delivery side, the sluice valve being installed on the upstream side of the non-return valve. A pressure gauge shall also be provided between the pump and the non-return valve. The size of the non-return valve and cut off (sluice) valve shall not be less than the size of the initial delivery pipe and, in no case, less than the delivery outlet of the pump. No butterfly valves shall be installed inside the pump room.

Sluice valve shall conform to IS: 780.

Butterfly valve, wherever used, shall conform to IS:13095.

All valves shall be suitable to with-stand the pressure in the system and rating shall be PN 1.6. All valves shall be right handed (i.e. handle or key shall be rotated clock wise to close the valve), the direction of opening and closing shall be marked and an open/shunt indicator fitted.

- (i) The material of valves shall be as under:
 - Body - Cast iron
 - Disc - Cast Bronze or Stainless Steel
 - Seat - Either integral or Nitrile rubber
 - O-ring - Nitrite/Silicon
- (ii) Non return valves shall be swing check type in horizontal run and lift check type in vertical run of pipes. Air release valves shall be of gunmetal body.

7.7 ISOLATION VALVES :

- (i) Isolation valves shall be provided in the network to enable isolation of any section of the network without affecting the flow in the rest. These valves are distributed according to the general layout of the installation. The isolation valves shall be normally located near the loop junctions. Additional valves shall be provided in the segments where the length of the segment exceeds 300 m.
- (ii) Cut-off valves shall conform to IS 780 (PN 1.6 rating)/IS 14846, Class 3.

- (iii) Butterfly valves can be accepted subject to the condition that the valves of diameter exceeding 150 mm shall necessary be of gear operated.
- (iv) All Cut-off valves shall be of the right-hand type and enclosed in properly constructed surface boxes, at least 1 m² in area so as to allow for broken joints being easily remade. The top of the surface box shall be 80 mm aboveground level, except where it is located on a road. Valve wheels shall have an arrowhead engraved or cast thereon showing direction for turning open and close.
It is recommended that the position of the surface box be indicated by an iron plate painted fire red with distinct lettering. Such plates shall also show the open and close direction as cast or indicated on the valves and the serial number of the sluice valve.
- (v) Locations where vehicles can pass shall be avoided for provision of valve below ground. (CPWD Specs Para 7.10 (xii))
- (vi) In case of installations in earthquake prone zones, flexible couplings shall be used for jointing purposes at required locations.

7.8 Valves in fixed firefighting installations shall have supervisory switch with its signalling to fire alarm panel or to have chain(s), pad lock(s), label and temper-proof security tag(s) with serial number to prevent tempering/unauthorized operation. These valves shall be kept in their intended 'open' position.

7.9 STRAINERS

Stainless steel strainers shall have minimum 1 mm thick screen with 3 mm perforations. Strainers shall be provided with flanges.

7.10 ORIFICE PLATE

Orifice plate shall be made of 6 mm thick stainless steel and shall have an identification tag projecting beyond any flange between which it is clamped. The orifice shall be plain central hole without burs and diameter not less than one-half of the internal diameter of the pipe to which it is fitted.

7.11 INSTRUMENTS

- (i) Pressure gauge of appropriate range and 150 mm diameter size shall be provided.
- (ii) The pressure gauge shall be duly calibrated before installation and shall be complete with shut off valve.

7.12 AIR VESSEL

Air vessel shall be provided on top of each riser and shall be fabricated out of 8 mm thick M.S. Sheet. The ends shall be dished. This shall be of 250 mm diameter, 1.2 m high and installed vertically on suitable legs. The legs shall be provided with M.S. Plate of size 75 mm x 75 mm x 5 mm at the bottom so that the legs do not puncture the roof. The legs shall be grouted in CC foundation. Flange connection shall be provided for connection with wet riser pipe. Air release valve and pressure gauge with shut off valve shall be provided. The air vessel shall be tested at 25 kgf/cm² pressure before installation.

7.13 INSTALLATION

- (i) The installation work shall be carried out in accordance with the detailed drawings prepared by the contractor and approved by the Engineer-in-charge.
- (ii) In pipe above ground level, expansion loops or joints shall be provided to take care

- of expansion or contraction of pipes due to temperature changes.
- (iii) Tee-off connections shall be through equal or reducing tees, otherwise ferrules welded to the main pipe shall be used. Drilling and tapping of the walls of the main pipe shall not be resorted to.
 - (iv) Open ends of piping shall be blocked as soon as the pipe is installed to avoid entrance of foreign matter.
 - (v) Piping installation shall be supported on or suspended from structure adequately. The contractor shall provide, clamps, hangers etc. in accordance with Para 7.16.
Proper lines and levels shall be maintained while installing exposed pipes.
 - (vi) Pipe supports in pump house shall be floor mounted and of mild steel/
G. I. Spacing of pipe supports shall not be more than that specified below:

Nominal Pipe Size (mm)	Spacing (m)
20 and 25	2.00
32 to 125	2.50
150 and above	3.00

Extra supports shall be provided at the bends and at heavy fittings like valves to avoid undue stress on the pipes.

- (vii) Anti-vibration pads, springs or liners of resilient and non-deteriorating material shall be provided at each support, so as to prevent transmission of vibration through the supports.
- (viii) Pipe sleeves of diameter larger than the pipe by least 50 mm shall be provided wherever pipes pass through walls and the annular spaces shall be filled with felt and finished with retaining rings.
- (ix) (a) Vertical risers shall be parallel to walls and column lines and shall be straight and in plumb. Risers passing from floor to floor shall be supported at each floor by clamps as per Para 7.16.
(b) The space in the floor cut outs around the pipe work shall be closed using cement concrete (1:2:4 mix) or steel sheet, from the fire safety considerations, taking care to see that a small annular space is left around the pipes to prevent transmission of vibration to the structure.
(c) Riser shall have suitable supports at the lowest point.
- (x) Where mild steel pipes shall be buried under ground the same shall be treated in accordance with Para 7.5 before laying. The top of the pipes shall be not less than 1m below the ground level. Where this is not practicable, permission of the Engineer-in-charge shall be obtained for burying the pipes at lesser depth. Masonry or C.C. blocks shall be provided for supporting the pipes at interval in accordance with Para 7.11(vi). After the pipes have been laid, the trench shall be refilled with the excavated soil in layers of 20 cm and rammed and any extra soil shall be removed from the site of work by the contractor.
- (xi) Underground pipe shall be laid at least 2m away from the face of the building preferably along the roads and foot paths. As far as possible laying of pipes under road, pavement and large open spaces shall be avoided. Pipes shall not be laid under buildings and where unavoidable, these shall be laid in masonry trenches with removable covers and cut-off valves shall be provided at points of entry and exit.
- (xii) Pipe over ground shall be painted in red color as per Para 1.13. Suitable identification shall be provided to indicate the run of underground pipe wherever the route of underground pipe cannot be ascertained from the location of yard hydrant/isolating valves.
- (xiii) It shall be made sure that proper noiseless circulation is achieved in the system. If proper circulation is not achieved due to air-bound connections, the contractor shall rectify the

defective connections. He shall bear all the expenses for carrying out the above rectification, including the tearing up and refinishing of floors, walls, etc. as required.

7.14 FLUSHING ARRANGEMENT

Flushing connections with isolation valves should be provided at suitable locations in the firewater ring main.

7.15 PRESSURE TESTING

- (a) All piping shall be tested to hydrostatic test pressure of at least one and a half times the maximum operating pressure, but not less than 10 kgf/sq.cm for a period not less than 24 hours. While Hydro Testing, inclusion of cut-off valves in the mains to be tested can be avoided. All leaks and defects in joints revealed during the testing shall be rectified to the satisfaction of the Engineer-in-Charge.
- (b) Piping repaired subsequent to the above pressure test shall be re-tested in the same manner.
- (c) System may be tested in sections and such sections shall be securely capped.
- (d) Pressure gauges may be capped off during pressure testing of the installation.

7.16 PIPE SUPPORTS

For installing pipes vertically or horizontally inside the building standard pipesupports of reputed make shall be used. Following supports shall be used.

- (i) Split pipe support clamps with rubber lining for vertical, horizontal and roofhanging.
- (ii) Clevis Hangers for horizontal supports to adjust varying heights.
- (iii) Sprinkler Hangers for horizontal supports for pipes from 15 mm dia to 150mm dia.

Fasteners and fully threaded rods shall be used for installing the pipe supports. The sizes of pipe supports and installation shall be in accordance with manufacturer's recommendations. Some of the typical supports are shown in the Figure-9.

For pipes of size 100 mm and above, with the prior approval of Engineer-in- Charge, 'U' clamp with dash fastener may be used for supporting horizontal pipe from ceiling.

7.17 MEASUREMENT

Measurements of plumbing work shall be on following basis:-

- (a) Piping shall be measured along the centre line of installed pipes including all pipe fittings and accessories but excluding valves and other terms for which quantities are specifically indicated in the schedule of work. No separate payment shall be made for fittings and accessories.
- (b) The rates for piping work shall include all wastage allowances, flanges pipe supports, hangers, excavation, refilling, testing, nuts and check nuts, vibration isolators, suspension where specified or required, and any other item required to complete the piping installation. None of these items will be separately measured and paid.

8. FIREFIGHTING ACCESSORIES

8.1 SCOPE

This chapter covers landing valves, first aid hose reels, hose pipes, branch pipes etc., which are vital tools for firefighting.

8.2 LANDING VALVE

Landing valves are provided in the system for connection of hose pipes for discharging water for fighting fire by fire brigade or trained personnel.

8.2.1 The landing valves shall be as per IS: 5290

8.2.2 Material of construction

- (i) Body, outlet and cap etc. : Bronze or Aluminum alloy or stainless steel
- (ii) Spindle : Brass for Bronze body, stainless steel for Aluminum alloy and stainless steel body.
- (iii) Hand wheel : Mild steel or cast iron.

8.2.3 The water discharge shall be not less than 900 lpm for single head valves at 7kgf/cm² pressure.

8.2.4 Installation

8.2.4.1 The landing valve shall be fitted to a T-connection of the riser at the landing in such a way that the valve is in the center of the internal hydrant opening and at a height of 900 mm from floor level.

8.2.4.2 The valve base shall be vertical and the valve facing outside. There should be no hindrance in operation of the handle.

8.3 FIRST AID HOSE REEL

First Aid Hose Reel is meant for delivering small quantity of water in early stage of fire and can be operated even by untrained personnel, and thus provides a most effective firefighting facility. It shall consist of 20 mm (nominal internal) diameter hose tubing length wrapped around a reel with water inlet pipe, stop valve and shut-off nozzle. The entire assembly is mounted on a wall bracket and can swing 180 degrees. The water inlet shall be connected directly to the riser/down-comer mains by means of 37 mm socket and valve. The hose tube can be pulled out easily for the purpose of discharge of water on fire.

8.3.1 First aid hose reel shall be as per IS-884. The coupling, branch pipe and nozzle shall be as per IS:8090.

8.3.2 Material of Construction -

- (i) Hub and sides : Aluminum Alloy / Mild steel / Aluminum sheets.
- (ii) Wall Bracket : Cast iron / Mild steel.
- (iii) Hose tube (20 mm nominal internal dia) : Thermoplastic (Textile Reinforced) Type-2 as per IS-12585

(iv) Nozzle with branch Pipe : Brass

(v) Stop Valve(Ball Valve) : Gun metal

Normally M S construction is used. Other material may be used in areas having corrosive atmosphere.

8.3.3 The water flow rate shall be not less than 24 lpm and the range of jet shall be not less than 6 m.

8.3.4 installation

8.3.4.1 First aid hose reels are installed with internal hydrant (Para 2.4.1.7.) space for which is provided as per Para 3.2.4. Where space is not provided, first aid hose reel shall be installed in suitable size MS cabinet made from 2 mm thick sheet with glass door. The cabinet shall be painted red as per Para 1.13. The size of the cabinet shall be such that there is no obstruction in swinging the hose reel. The location of cabinet shall be such that it does not form an obstruction in passage/escape route.

8.3.4.2 The length of hose tube shall be such that the nozzle of the hose can be taken into every room and within a range of 6 m from any part of the room.

8.3.4.3 There shall be no obstruction in swinging the hose reel and should be installed above landing valve where provided.

8.3.4.4 The inlet valve shall be at 900 mm above floor level.

8.3.4.5 Hose reel bracket should be firmly grouted on the wall with the help of rawl bolts.

8.4 FIRE HOSE DELIVERY COUPLING, BRANCH PIPE AND NOZZLES:-

8.4.1 These are important accessories used for firefighting operations.

8.4.2 Material of Construction

8.4.2.1 Copper Alloy

8.4.2.2 Aluminum alloy

8.4.2.3 Stainless Steel

8.4.3 Delivery Hose Couplings

8.4.3.1 The delivery hose couplings consist of male half coupling and female half coupling. Grooves are provided on outer side on both coupling for binding hose pipes with wires. In female coupling spring loaded cam tooth is provided for holding male half coupling in position. Male half coupling and female half coupling are provided on both sides (i.e. on

one side male and on other side female) of hose pipes. Two or more pipes can be joined together with the help of these couplings instantaneously.

8.4.3.2 Sizes:- These are available in two sizes i.e. 63 mm and 70 mm. Normally size 63mm is used.

8.4.4 Branch Pipe and Nozzle :- Branch Pipes with nozzle are mounted at the end of hose pipe. Branch pipe is properly finished and free from sharp edges. During operation, a fireman has to hold the branch pipe. One end of branch pipe is fixed with hose coupling and the other end is threaded to fit the nozzle.

Nozzle is tapered pipe with one end threaded internally which is fixed on branch pipe. The size of other end i.e. nozzle shall be 20 mm (nominal internal diameter).

Spare Branch pipes and nozzles to the extent of 10 percent of the above requirements, with a minimum of two sets, shall always be kept readily available in fire control room/pump room.

8.5 FIRE SERVICE INLET AND FIRE SERVICE CONNECTION

8.5.1 These are provided for connection of fire service hose pipes for either directly pressurizing the system with their pumps or filling water in the tank from a distance. In the first case non-return valve with butterfly valve shall be provided for holding water pressure. Fire service inlet shall be provided with each wet riser/down comer and the ring main. The arrangement has been shown in Fig.5. These are fixed to 150 mm diameter pipe and located in MS Box made of 2 mm thick mild steel sheet with openable glass cover.

8.5.2 These shall be as per IS: 904.

8.5.3 Material of Construction

8.5.3.1 Copper Alloy

8.5.3.2 Aluminum Alloy

8.6 HOSE PIPES

8.6.1 Hose pipes shall be rubber lined woven jacketed and 63 mm in diameter. They shall conform to Type A (Re-inforced rubber lined) of IS: 636. They shall be flexible and capable of being rolled. Length of hose pipe will be 15 m.

8.6.2 The hose pipe shall be complete with male and female coupling at the ends as per Para 8.4.3.

Besides keeping hose pipe with internal hydrant and yard hydrant, spare hose pipes to the extent of 10 percent of the above requirements, with a minimum quantity of 30 m shall always be kept readily available in fire control room/pump room. Such spare hose shall be in 15 m lengths, readily attached to couplings.

9. AUTOMATIC SPRINKLER SYSTEM

9.1 SCOPE

This chapter covers the general requirement of selection, design, installation, testing,

commissioning and maintenance of automatic sprinkler system for firefighting in buildings used for other than industrial, storage purpose, hotels and mercantile buildings.

9.1.1 **References:** For additional information regarding definitions, planning, design, hydraulic calculations, tables etc. following documents are to be referred to:

- (i) IS: 15105: - Design and Installation and Maintenance of Fixed Automatic Sprinkler Fire Extinguishing Systems- Code of Practice (First Revision).
- (ii) IS: 9972: - Specification for Automatic Sprinkler Heads for Fire Protection Service (First Revision).

9.2 INTRODUCTION

Firefighting installations described in Para 2.2.1 (i) to (iii) are to be operated manually. Delay in undertaking manual operation due to late detection and or response, may result in spread of fire. In automatic sprinkler system, sprinkler heads are provided throughout the areas to be protected at specified locations such as roof or ceiling, walls, between racks, below obstructions and fitted with water supply lines permanently charged with water under specified pressure. The sprinklers operate at pre-determined temperature to discharge water over the affected area below and provide an adequate distribution of water to control or extinguish fire. Only those sprinklers which are in the vicinity of fire that is those become sufficiently heated operate. Operation of sprinkler results in flow of water which initiates fire alarm. Thus sprinklers perform two functions i.e. first to detect fire and then to provide an adequate distribution of water to control or extinguish it. Water distribution from ceiling level, cools down the hot gas which forms beneath the ceiling of enclosure in which fire is developing. This will prevent spread of fire to adjoining areas and contain damage to limited area.

It should not be assumed that the provision of sprinkler system entirely obviates the need for other means of fighting fire and it is important to consider the fire precaution in the premises as a whole.

The system shall be installed only where there is no danger of freezing of water in the pipes at any time.

Typical layouts of sprinklers have been shown in Figure 11.

9.3 CLASSIFICATION OF OCCUPANCIES AND PROVISION OF AUTOMATIC SPRINKLER FIRE SYSTEM

Sprinklers are provided in industrial and non-industrial buildings. The design of sprinkler installation depends upon type of occupancy. For the purpose of designing and installation of automatic sprinkler system, buildings are categorized under the following classes in IS: 15105.

- (a) Light hazard class
- (b) Moderate/Ordinary hazard class
- (c) High hazard class
- (d) Storage hazards

For details of classifications, IS: 15105 is to be referred. Light Hazard Occupancies shall be understood as those with low fire loads and with materials within having low rates of heat release. Light Hazard Occupancies are of non-industrial type subject to the condition that "No single compartment greater than 210 m² are allowable within light hazard occupancies and such compartments shall be fire separated by walls having 30 min rating and doors. Otherwise the sprinkler system shall be designed as per Ordinary Hazard Occupancy."

Office buildings (excluding store rooms), education institutions, hospitals (excluding kitchens, stores, utilities), libraries, museums, nursing homes, prisons and residential apartments are classified under light hazard occupancies.

Airport terminal buildings, car parking areas within building or basement, departmental stores/retail shops are classified under ordinary hazard class.

In order to satisfy above conditions, all buildings classified under Light Hazard shall be designed under Ordinary Hazard class. Accordingly these specifications cover Ordinary Hazard class only.

9.4 PLANNING

- 9.4.1 Automatic sprinklers shall be installed wherever required in terms of Table 7 of Part-4, Vol-1 of NBC 2016 (amended up to date). These requirements for installation of automatic sprinkler system have been reproduced in Appendix-A.
Automatic Sprinklers shall also be installed in false ceiling voids exceeding 800 mm in height.

Ramps at all levels shall also be protected with sprinklers

Pressure in the sprinkler installation piping shall not exceed 7 bar and pressure at the most remote sprinkler at any level shall not be less than 0.5 bar and also not more than 5 bar.

Extent of Sprinkler Protection: -

Sprinklers shall be provided, but for following exceptions:

- (a) Areas, rooms or places where the water discharged from a sprinkler may pose a fire or explosion or toxic hazard. In such areas alternative arrangement shall be made.
- (b) Stairs, spaces below stair headings (but not rooms above a stair) and lift wells. Any part of the building not provided with sprinkler protection shall be fire separated by walls. Fire doors not less than 1 hour in fire resistance shall be provided in the opening of such walls.
- (c) Wash rooms, toilets and WCs (but not cloak rooms) of area less than 5m². If area of these rooms exceed 5m², these shall be provided with sprinkler protection unless fire separated by walls and all openings in the walls are protected.
- (d) Sprinklers shall not be required in electrical equipment rooms where all of the following conditions are met:
 - i) The room is dedicated to electrical equipment only.
 - ii) Only dry-type electrical equipment is used.
 - iii) Equipment is installed in a 120 minutes fire-rated enclosure including protection for penetration in walls.
 - iv) Cable coating is done in trays or trenches to prevent flame spread.
 - v) Storage is not permitted in the room.In addition, for fire-fighting provisions to be provided for Substation/Transformers, Electrical MV main distribution panel and lift panel *Clause 3.4.6.3 and 3.4.6.4, Page-22-23 of NBC 2016, Vol-1, Part-4 may be referred to. (see Appendix-G)*
- (e) Rooms like server room or electrical control room where alternate protection by other automatic extinguishing systems, (for example gas, powder and water spray).
- (f) In areas having height 17 m or above such as in atria, sprinkler installations may be rendered ineffective and hence may be avoided.

- 9.4.2 The area to be protected by sprinkler is divided in to various zones. For detecting operation of sprinkler in a zone, flow switches are provided which are wired to an annunciation panel installed in the Fire Control Room. In the event of operation of sprinkler(s) in an affected area. The annunciation panel will give audio-visual alarm and indicate the affected zone. This arrangement will be independent of fire alarm system.

- 9.4.3 Design, Density and Assumed Maximum Area of Operation (AMAO):- This is different for different hazards classified in Para 9.3. For moderate hazard, water discharge shall be at least 5 litre/min/m² over an assumed area of operation covering 360 m².
- 9.4.4 Sprinkler Spacing, Arrangement, Distribution and Locations:- Sprinkler heads may be installed on ceiling and or side walls. For selection of number of sprinkler and their location in a given area, following factors shall be considered:
- (i) Maximum Area Coverage per Sprinkler
 - (a) Ceiling sprinkler 12 m²
 - (b) Side wall sprinkler :
 - Combustible ceiling 7.5 m²
 - Non-Combustible ceiling 9 m²
 - (ii) Maximum Distance between Sprinklers
 - (a) Ceiling sprinkler 3.5 m
 - (b) Side wall sprinkler
 - Combustible ceiling 2.7 m
 - Non-combustible ceiling 3 m
 - (iii) Minimum Distance between Sprinklers 1.8 m
(for Ceiling as well as Sidewall sprinklers)
Note: In case of intermediate ceiling suspended sprinklers, protecting commodities in racks, distance lower than 1.8 m may be considered if necessary.
 - (iv) Maximum distance of sprinklers it shall not exceed from
end walls : half of the allowable
(for ceiling & sidewall sprinklers) distance between sprinklers
Note:
For ceiling sprinklers:
 - a) where the external walls are combustible or built with metallic or otherwise or open sided; and in case of open joisted ceilings or where the roof has the rafters exposed, the distance between the boundary and the sprinklers shall not exceed 1.5 m.
 - b) Distance shall be measured perpendicular to the wall.
 - (v) Sprinklers shall not be located at a distance less than 100 mm from the wall (for ceiling sprinklers).
Sprinklers shall not be located at a distance less than 100 mm from the end wall (for sidewall sprinklers)

While designing sprinklers installation, the recommendation of sprinkler manufacturer shall be considered. Typical layout of side wall sprinklers has been shown in Figure 14.

- 9.4.5 **Spacing below Sprinkler Heads:** - Clear minimum space of 0.5 m shall be maintained below the deflector of sprinkler head.

9.4.6 Ceiling Sprinkler deflector location and orientation in relation to building structure:

9.4.7 9.4.7.1 Roofs and ceilings:

For conventional and spray type of sprinklers, the sprinklers shall be installed in such a way that the deflectors are at distances below ceilings as shown in Table 9.1.

<p align="center">Table 9.1 Sprinkler Location Below Ceilings [Clause 9.4.7.1]</p>

S. No.	Type of ceiling	Distance below ceilings (in mm)		
		Minimum	Maximum	Preferred
(1)	(2)	(3)	(4)	(5)
i)	Combustible, asbestos cement sheets, wired glass and other types of frangible	75	300	150
ii)	Combustible with exposed rafters and/or open joists	75	150	-
iii)	Non combustible - either plane or arched or sloping	75	450	300


9.4.8 Sidewall Sprinkler Deflector Location and Orientation in relation to building structure:

- Distance between sprinklers and the ceiling shall not exceed 150 mm. If specifically approved for use and listed so, the distances between ceilings and the sprinklers can be increased up to 450 mm.
- Vertical side wall sprinkler deflectors shall be located not more than 150 mm or less than 100 mm from the wall from which they are projecting.
- Sprinklers shall be so located to minimize obstructions (to discharge) either on parallel or perpendicular sides thereof. If required, additional sprinklers shall be provided to obviate the obstructions.
- Sidewall Sprinkler Obstruction:** Sprinklers shall be located at least 1.2 m away from any lighting, fan and similar fixtures either in front of or on the same wall where the sprinklers are mounted. For any obstruction (to discharge) including lighting, fan and the like beyond 1.2 m, distances A and B (as indicated in Fig. 9.2 and 9.3) shall be maintained as per the Tables 9.2 and 9.3 given below. In case these distances can not be maintained, the sprinkler shall not be allowed at such location. (See Fig. 9.2 and 9.3).
- Clearance between the top of storage if any to the deflector shall not be less than 450 mm.
- Side wall sprinklers in rooms shall neither be installed above the grills of air conditioner nor within 450 mm thereof on the same wall.

Table 9.2 Sidewall Sprinkler Location in Relation to Obstructions (lighting, fan and similar fixtures) -Facing across the wall (see Fig. 9.2)(Clause 9.4.8 iv)		
S. No.	Distance (A) between Sprinklers and the Obstruction on Side (mm)	Maximum allowable Distance (B) between Deflector above bottom of Obstruction when Sprinkler can be allowed (mm)
(1)	(2)	(3)
a)	Up to 1200	Not allowed
b)	More than 1200 but less than 1500	25
c)	More than 1500 but less than 1650	50
d)	More than 1650 but less than 1800	80
e)	More than 1800 but less than 1950	100
f)	More than 1950 but less than 2100	150
g)	More than 2100 but less than 2250	180
h)	More than 2250 but less than 2400	230


i)	More than 2400 but less than 2550	280
j)	More than 2550	350

Table 9.3 Sidewall Sprinkler Location in Relation to Obstructions (lighting, fan and similar fixtures)-Along the same wall (see Fig. 9.3) (Clause 9.4.8 iv)		
S. No.	Distance (A) Between Sprinklers and the Obstruction on Side (mm)	Maximum allowable Distance (B) between Deflector above bottom of Obstruction when Sprinkler can be allowed (mm)
(1)	(2)	(3)
a)	100 to 150	25
b)	More than 150 but less than 300	50
c)	More than 300 but less than 450	80
d)	More than 450 but less than 600	115
e)	More than 600 but less than 750	150
f)	More than 750 but less than 900	180
g)	More than 900 but less than 1050	200
h)	More than 1050 but less than 1200	230
i)	More than 1200 but less than 1350	250
j)	More than 1350 but less than 1500	300
k)	More than 1500 but less than 1650	330
l)	More than 1650 but less than 1800	350
m)	More than 1800 but less than 1950	380
n)	More than 1950 but less than 2100	430
o)	More than 2100 but less than 2250	450



ELEVATION VIEW

Fig.9.2 SIDEWALL SPRINKLER FACING OBSTRUCTION



- v) Horizontal sidewall sprinkler shall be located not more than 100 mm and are allowed to be located with their deflectors less than 100 mm from the wall on which they are mounted.
- vi) Deflectors of the sprinklers shall be aligned parallel to the ceilings or roofs.
- vii) When installed under a sloped ceiling (1 in 6), sidewall sprinklers shall be located at the high point of slope and positioned so as to discharge down the slope.
- viii) Where vertical side of a beam/projection from a wall is used for installing a sidewall sprinkler, additional sprinklers shall be installed below the soffit if the width of beam or projection from the wall exceeds 200 mm.
- ix) When soffits used are within 200 mm in width or projection from the wall, additional sprinklers shall not be required subject to the deflector of the sprinklers falling within prescribed distance as contained in 9.4.8 (ii), (vi) & (vii) above.

9.4.9 Concealed Spaces:-

9.4.9.1 If the height of the concealed space at roof and floor is not greater than 0.8m, the spaces shall be sprinkler protected only if they contain combustible materials or are constructed with combustible materials. Electrical cables with voltage less than 250 V, single phase, with a maximum of 15 cables per tray, are allowed.

9.4.9.2 Spaces between roofs and ceiling more than 0.8 m deep shall be sprinkler protected as follows:-

- (i) Concealed spaces less than 5m² in area shall not require sprinkler protection.
- (ii) Sprinkler heads shall be provided considering the space as any other area in the building.
- (iii) Sprinkler heads may be connected individually with the range/distribution pipes below, which shall be sized by taking the room and concealed space sprinklers cumulatively.
- (iv) Sprinkler heads for concealed space and for the room may be connected with separate range/distribution pipes connected, with common feed pipe. The common feed pipes shall be not less than 65 mm diameter.

9.4.10 **Obstruction below Sprinklers:-** Sprinklers shall be fitted under the following types of obstruction which are either:

- (a) more than 0.8 m wide and less than 150 mm from the adjacent walls or partitions

OR

(b) more than 1 m wide.

- 9.4.11 **Pipe Sizing and Design:** - Sprinkler heads located as per Para 9.4.5 to 9.4.10 shall be connected with pipe lines permanently charged with water. Depending upon location of sprinkler heads and site conditions, sprinkler heads may be connected with range and distribution pipes. A number of options have been indicated in Figure-12.

The pipes connecting the sprinkler heads are to be sized depending upon number of sprinkler heads and arrangement of their connection. Main elements of a sprinkler installation are shown in Figure-11. Various pipes connecting the sprinkler heads are termed as below:

- (a) Range Pipe
- (b) Distribution Pipe
- (c) Main Distribution Pipe
- (d) Riser

Sizes of pipes are to be calculated from various tables and hydraulic calculations given in IS: 15105.

Pipe sizes shall be determined using one of the following methods:

- a) **Pre-calculated system:** applicable only where light and ordinary occupancies where the aggregate floor plate area (in one or more floors combined) is 5000 m² or less (except where gridded or looped layouts are used).
Pre-calculated pipework is applicable only to the extensions of old pre-calculated systems.
- b) **Fully calculated system:** applicable for
 - i) Light and ordinary occupancies where the aggregate floor plate area (in one or more floors combined) exceeds 5000 m².
 - ii) High hazard occupancies,
 - iii) Storage occupancies, and
 - iv) All occupancies where conventional and special sprinklers are used like ESFR, LD, EC, intermediate, etc.

Some guidelines relating to pre-calculated system are given below:

- a) Pipe less than 25 mm diameter is not to be used.
- b) There shall not be more than 6 (Six) sprinklers in any range.
- c) Range and distribution pipe nominal sizes shall be selected from Table 9.4 and Table 9.5 respectively.

TABLE 9.4
**RANGE PIPE NOMINAL SIZES FOR VARIOUS PIPE LAYOUTS IN
 MODERATE/ORDINARY HAZARD INSTALLATIONS**

	Range Pipe Layout	Pipe Nominal Bore (mm)	Maximum Number of Sprinklers to be fed by Pipe of size listed
	(1)	(2)	(3)
(a)	(1) Range(s) at remote end of each distribution pipe spur in end feed layout:		
	(i) Last two ranges in two end-side layout	25	1
		32	2
	(ii) Last three ranges in three end-side layout	25	2
		32	3
	(2) Last range in all other layouts.	25	2
		32	3
		40	4
	(b) All other ranges in case of (i), (ii) & (2) above	25	3
		32	4
		40	6

TABLE 9.5
**DISTRIBUTION PIPE NOMINAL SIZE IN MODERATE/ORDINARY
 HAZARD INSTALLATIONS AND MAXIMUM NUMBER OF SPRINKLERS**

Distribution Pipes	Type of Layout	Distribution Pipe Nominal (mm)	Maximum Number of Sprinklers to be fed by Pipe size listed
(1)	(2)	(3)	(4)
(a) At extremities of the Installation	Two end side layouts	32	2
		40	4
		50	8
		65	16
(b) Last three ranges	All other layouts	32	3
		40	6
		50	9
		65	18
(c) Between design points	All	To be calculated as per 10.4.4 (b) of IS15105	

and the Installation Control Valve		
--	--	--

Typical pipe sizes for sprinkler installation have been shown in Figure-13.

9.4.12 **Components of sprinkler system:-** Following types of valves are used in the installations:

- (a) Stop Valves
- (b) Test Valves
- (c) Drain Valves
- (d) Flushing Valves
- (e) Check Valves
- (f) Installation Control Valves
- (g) Pre action valves
- (h) Subsidiary valves

The location of above valves shall be as under:

9.4.12.1 **Test Valve.** - For testing hydraulic alarm or electric alarm by drawing water from downstream side, test valve shall be connected with downstream of the water flow alarm.

9.4.12.2 **Drain Valve:** - For drainage of system, drain valve 50 mm diameter shall be provided down stream of Installation Control Valve or any subsidiary stop valve.
A common valve can perform the functions of test and drain. The outlet shall be connected with a 50 mm diameter G.I. drain pipe along with riser pipes as shown in figure No. 3 and 4.

9.4.12.3 **Flushing Valve:-** If the water used for sprinkler is not potable, flushing valves shall be provided at the end of a distribution pipe. The valve size shall be same as distribution pipe. Valve outlet shall be fitted with a brass plug and extended to not more than 3 m above floor.

9.4.12.4 **Check Valve:-** Check valve shall be provided where more than one water supply is available and same shall be fitted on each water supply pipe.

9.4.12.5 **Subsidiary Stop Valve:-** Subsidiary stop valve which shall be of the same diameter as the pipe line in which they are fitted shall be provided to control water supply to sprinklers of highly sensitive areas like computer rooms.

9.4.12.6 **Installation Control Valve (ICV):** - A sprinkler installation shall be fitted with a suitable Installation Control Valve to control the water supply to the installation. The valve set shall comprise of:

- (a) a main stop valve.
- (b) an alarm valve.
- (c) a water motor alarm.

The alarm valve shall be fitted immediately downstream of the main stop valve of each

building/block and before any connection is taken off to supply any part of the installation.

The Installation Control Valve shall be placed externally in the vicinity of the main entrance of the building protected at an easily accessible place so that the alarm bell sound is heard by the inhabitants/passers-by. The valve shall be secured open by a pad locked or rivetted strap and protected against impact damage.

If there are genuine constraints in locating the Installation Control Valve outside the buildings, this may be located inside the building in the vicinity of main entrance (subject to approval of authorities concerned). Installation Control Valve in such cases, shall be located away from any exposure to damage and personnel shall be normally available in the vicinity of the location to get alerted by alarm operation. Also, electrically operated sirens interfaced with the opening of the alarm valve of ICV, shall be provided outside the building. In no case, Installation Control Valve shall be provided inside basement or inside pump room.

A plan of the risk with the position of Installation Control Valve shall be placed in a conspicuous location. A location plate shall be fixed near the Installation Control Valve bearing the following words in raised letters:

SPRINKLER ALARM

9.4.12.7 Water motor alarm: Water motor alarm shall be provided very close to the alarm valve. Strainer shall be fitted between the alarm valve and the motor nozzle connection. The water outlet shall be positioned so that any flow of water can be seen. The alarm device shall provide audibility level of 85 dB above the background noise level.

9.4.12.8 Pressure Gauges: - Pressure gauges shall be provided immediately above and below each alarm valve.

Stop cock shall be provided before pressure gauges for removal without interruption of water supply of the installation. Pressure gauges shall be as per IS: 3624.

9.5 SPRINKLERS TYPE

Sprinklers shall be as per IS: 9972 and following types:

9.5.1 According to type of discharge (*Refer Figure - 15*):

- a) Conventional pattern
- b) Spray pattern
- c) Side wall pattern

9.5.2 According to mounting pattern:

- a) Pendent sprinkler
- b) Up right sprinkler
- c) Horizontal sprinkler

9.5.3 Ceiling sprinkler According to Release Mechanism:

- a) Fusible element sprinkler

b) Glass bulb sprinkler

9.5.4 According to Orifice Size:

- a) 10 mm
- b) 15 mm
- c) 20 mm
- d) 25 mm

9.5.5 According to Temperature Rating:

Sprinkler shall have one of the following temperature rating and shall be correspondingly color coded:

(a) Fusible Link Type

Temp. Rating °C	Color Code
68/74	Natural
93/100	White
141	Blue
182	Yellow
227	Red

(b) Glass Bulb Type
Temp. Rating

Temp. Rating	Color of bulb Liquid
57	Orange
68	Red
79	Yellow
93	Green
141	Blue
182	Mauve
204/260	Black

9.6 SELECTION OF TEMPERATURE RATING

Temperature rating of a sprinkler should not be less than 30° C more than the highest anticipated temperature of the location of installation. Under glazed roofs or where there are roof sheets of PVC or similar plastic material, sprinkler shall be rated 73° C to 100° C.

9.7 SELECTION OF ORIFICE SIZE

In moderate hazard applications, sprinklers of orifice size 15 mm shall be used.

Table-9.6 Types of sprinkler			
S. No.	HAZARD CLASS	SPRINKLER PATTERN	NOMINAL ORIFICE NOT LESS THAN MM
(1)	(2)	(3)	(4)
i)	Light	Standard, Spray, Flush, Sidewall types	10-15
ii)	Ordinary	All except sidewall types	15
iii)	High	Standard, spray pattern only	15-25
iv)	Storage	Standard, spray pattern only	15-25

9.8 SIZE OF INSTALLATIONS

The protected floor area to be controlled by any one Installation Control Valve shall not exceed 12000 m².

As far as possible one area shall be controlled by one Installation Control Valve. If the area is quite large, more than one Installation Control Valve should be planned. Details of area controlled by an Installation Control valve shall be exhibited near it.

If there are more than one block in a campus, each block shall be provided with different Installation Control valve.

9.9 PROTECTION OF SPRINKLERS

Any sprinkler installed in a position of risk or accidental damage shall be fitted with a metal guard suitable for sprinkler service.

9.10 WATER SUPPLY ARRANGEMENT FOR SPRINKLER

9.10.1 Pump- Details of pumps to be installed for sprinkler installation are given in Appendix-A. For large installations, separate jockey pump shall be provided for sprinkler system. All pumps shall have common discharge header. If two electrical pumps are to be provided one non-return valve shall be provided in the header such that sprinkler pump will not feed other system.

9.10.2 Water Storage Tank- The water storage tank shall be combined for other firefighting system and sprinkler installation and the capacity shall be as given in Appendix 'A'.

9.11 SPRINKLER ANNUNCIATION PANEL AND ALARM

Electrically operated alarm shall be provided for indication of operation of sprinkler in an area. Water flow switches shall be installed in main distribution pipes which shall be wired to sprinkler annunciation panel. In the event of operation of a sprinkler, the flow switch will operate and give signal to the annunciation panel to indicate operation of sprinkler in the area. This will initiate an electrically operated alarm. The system shall

be independent of fire alarm system and compatible with BMS. Necessary potential free contacts for use in BMS should be provided.

9.11.1 Construction Details

- (i) The Panel shall be fabricated out of not less than 2 mm thick MS sheet and powder coated after 7 tank treatment process and shall be totally enclosed dust damp and vermin proof. Suitable knockout shall be provided for the entry of cables. The panel shall be designed such that the equipment for power supply, battery charging are housed in independent compartments. Sealed maintenance free batteries shall also be accommodated inside the panel.
- (ii) Indicating lamps control switches, buttons and fuses shall be suitably located in the front and properly labeled.
- (iii) The indicating lamps shall be LED type of following colors. The flow switch operation conditions shall be indicated by twin lamps.
 - (a) Red to indicate flow switch operation.
 - (b) Amber to indicate fault condition.
 - (c) Green to indicate healthy condition.
- (iv) The test buttons to test the indication lamps shall be provided.
- (v) The panel control shall be microprocessor type.
- (vi) The primary function of the panel shall be to respond automatically to the operation of one or more flow switches to give alarm and to indicate area/areas where the device has activated. The operation of one or more flow switches shall result in simultaneous alarm given by the following:-
 - (a) External alarm hooter(s) (provided outside the building to be protected).
 - (b) A visible indication on panel.
 - (c) Audible alarm on panel itself (common for all zones)
- (vii) The panel shall indicate the fault within the system and immediate fault warning shall be given by an audible and visible signal on the panel in case of open circuit, short circuit and earth fault in cable between flow switch and annunciation panel.
- (viii) The panel shall be complete with mimic diagram for the areas covered by different flow switches. The layout of mimic diagram shall be got approved from Engineer-in-Charge.
- (ix) Battery backup with trickle cum boost charger shall be provided for operation of the system. Indication of mains failure and the state of charge of the batteries shall be provided. The batteries shall be sealed maintenance free. The capacity of the battery shall be 12 Volt, 2 Nos. 24Ah each. All standard accessories shall be provided.

9.12 INSTALLATION

The installation shall be carried out as per Chapter 7 and 11. Following additional points are to be taken care for sprinkler installations:

- 9.12.1 For fixing sprinkler heads, 15 mm diameter M.S. Socket is to be welded to range pipes at the locations as per drawings. Dead plug shall be fixed in the socket.
- 9.12.2 If sprinkler head is to be provided away from range pipe, M.S. Pipe nipple of suitable size be used to extend the sprinkler head and socket is welded at desired location.
- 9.12.3 After completion of work in sections, pressure testing at 7.5 kgf/cm^2 pressure shall be carried out for 24 hrs.

- 9.12.4 After completion of the entire work, pressure testing of entire pipe work shall be carried out for 24 hrs. at a pressure of 7.5 kgf/cm². The drop of pressure up to 0.5 kgf/cm² shall be accepted.
- 9.12.5 The lines shall be flushed before completion of building work so that any foreign matter which might have entered the system is taken out. The pressurization pump (Jockey Pump) be operated and valves opened at different locations.
- 9.12.6 During occupation of the building, sprinkler heads shall be provided in place of dead plugs. Teflon tape shall be used on threaded portion. The sprinkler heads shall be properly tightened in the socket.
- 9.12.7 When all sprinklers heads are installed, pressure is built up in the system by pressurization pump slowly and in case no leak is found, desired pressure is developed and maintained. In case any leak is detected, the same shall be attended before pressurizing the system further.

9.13 COMMISSIONING

As soon as the work is complete, the system shall be commissioned and made available for use in accordance with Para 11.6.

9.14 Spare Sprinklers to be Kept in Stock :

A stock of spare sprinklers shall be maintained in the premises so that prompt replacement is possible after the operation/damage of sprinkler heads. The spares shall be kept in an easily accessible location under conditions where the temperature does not exceed 38°C.

The guidelines as in Table 9.7 shall be followed in respect of stocking spare sprinkler heads.

Spanners or wrenches for the sprinklers shall also be kept along with the spare sprinklers in readiness.

Table 9.7

Guidelines for stocking spare sprinkler			
S. No.	HAZARD CLASS	All state capitals and within 200Km thereof	Other locations
(1)	(2)	(3)	(4)
i)	Light	5 sprinklers of each type	15
ii)	Moderate/Ordinary	15 sprinklers of each type	25
iii)	High & storage	30 sprinklers of each type	50
Note- When there is more than one installation within a complex, the above quantity shall also be increased in proportion. Each type of sprinkler used in the installation such as conventional or spray or ceiling/flush or sidewall sprinklers and appropriate temperatures shall be stocked as per the above requirements.			

10. ELECTRICAL WORK

10.1 SCOPE

This chapter covers the requirements for the electrical works associated with firefighting installations, namely, motors, switch boards, power cabling, control wiring, earthing and remote control-cum-indicating panels.

10.2 GENERAL

- (i) Unless otherwise specified in the tender specifications, all equipment and materials for electrical works shall be suitable for operations on 415 V / 240 V + 10% (3 phase/single phase), 50 Hz AC system.
- (ii) All electrical works shall be carried out complying Central Electricity Authority (Measures Relating To Safety and Electric Supply) Regulations, 2010 and NEC 2011, as amended up to date.
- (iii) All parts of electrical works shall be carried out as per appropriate CPWD General Specifications for Electrical works, namely, Part I (Internal) 2013, Part II (External) 1994 work, and Part IV (Sub-station)- 2013 all as amended up to date.
- (iv) All materials and components used shall conform to the relevant IS specifications amended to date.

10.3 POWER SUPPLY

Power supply to following systems and equipment, where provided, shall be from normal and emergency (standby generator) power sources with changeover facility:

- a) Fire pumps
- b) Pressurization and smoke venting; including its ancillary systems such as dampers and actuators.
- c) Terrace pump
- d) Fireman's lifts (including all lifts).
- e) Exit signage lighting.
- f) Emergency lighting.
- g) Fire alarm system.
- h) Public address (PA) system (relating to emergency voice evacuation and annunciation).
- i) Magnetic door hold open devices.
- j) Lighting in fire command center and security room.

The generator shall be capable of taking starting current of all the fire and life safety systems and equipment as above. Where parallel HV/LV supply from a separate substation fed from different grid is provided with appropriate transformer for emergency, the provision of generator may be waived in consultation with the Authority.

The electric supply to the pumping set(s) shall be entirely independent of all other equipment in the premises that is even when the power throughout the entire premises is switched off, the supply to the pump shall continue to be available un-interrupted. This can be achieved by taking the connection for the pump(s) from the incoming side of the main L.T. breaker. In case, where parallel HV/LV supply from a separate substation fed from different grid is provided with appropriate transformer for emergency connected to a common bus bar, the connection may be taken through the bus bars.

The power supply to the panel/distribution board of these fire and life safety systems shall be through fire proof enclosures or circuit integrity cables or through alternate route in the adjoining fire compartment to ensure supply of power is reliable to these systems and equipment. It shall be ensured that the cabling from the adjoining fire compartment is protected within the compartment of vulnerability. The location of the panel/distribution board feeding the fire and life safety system shall be in fire safe zone ensuring supply of power to these systems.

Circuits of such emergency system shall be protected at origin by an automatic circuit breaker so set as to permit the motor to be overloaded during an emergency to the maximum limit permissible by the manufacturer. Further, the no volt coil/the under voltage release of that circuit breaker shall be removed. Master switches controlling essential service circuits shall be clearly labeled.

- 10.3.1 Independent supply shall be provided for water supply pumps if installed in the same pump house.
- 10.3.2 If the fire pump house is away from the sub-station building, the route of the cable shall not pass under the building or permanent structure. Cable shall be laid along the route which is safe from fire.
- 10.3.3 Sufficient spare power shall always be available to drive pumping sets at all times throughout the year. Suitable capacity ACBs/SDFUs shall be provided in the electrical panel for extending supplies to fire pumps. Such switches shall be suitably marked "FIRE SWITCH" and shall not be switched-off without permission/intimation to appropriate authority. In case any maintenance/repair work is to be carried out on the electrical panel where from supplies to fire pumps have been extended, alternative arrangement shall be made to ensure that power supply to fire pumps continue to be available for operation any time.

10.4 MOTORS

The motors shall be squirrel cage AC induction type. The motors shall be suitable for continuous duty and rating necessary to drive the pump at 150 percent of its rated discharge with at least 65 percent rated head. The motor shall be totally enclosed fan cooled type conforming to protection class IP 21 of IS: 4691. The class of insulation shall be 'F'. The synchronous speed shall be 1500/3000 rpm as per requirement of the pump. The motor shall conform to IS:325.

10.5 MOTOR STARTER

- (i) The motor starter shall conform to IS: 1822 "Motor starters of voltage not exceeding 1000 volts" and shall be air insulated and suitable for 415 V, $\pm 10\%$, 50 Hz, 3 phase AC supply and shall be integrated in the panel.
- (ii) Starter for the motor shall be direct on line (D.O.L) for motors up to and including 7.5 H.P. rating and automatic star-delta type for motors of higher ratings unless otherwise specified in the tender specifications. However, for main Fire Pump & Sprinkler Pump Soft Starters may be used.
- (iii) Each starter shall be provided with the following protections: -
 - (a) Thermal overload on all the three phases with adjustable settings,

- (b) Independent single phase preventer. (Current sensing type).
- (iv) Adequate number of extra NO/NC contacts for interlocks, indicating lamps, remote operation etc. shall be provided on the starter/contactors.
- (v) Under voltage/No volt trip shall not be provided.

10.6 SWITCH BOARDS

- (i) The main switch board shall be floor mounted, free standing or wall mounted cubical type and shall be factory built fabricated by one of the approved switch board manufacturer. The board shall be fabricated from 2.0 mm thick CRCA sheet and powder coated after 7 tank treatment process. The board shall be fabricated with IP 42 degree of protection. It shall be suitable for termination of the incoming cable(s) from bottom.
- (ii) The capacity of switch gear shall be suitable for the requirements of motor fed/ controlled. Starting currents shall be duly considered.
- (iii) Switch fuse units shall be used up to and including 32 A and SDFU shall be used for 63 A and above. ACB shall be used for 630 A and above ratings.
- (iv) All Switch fuse units/SDFUs shall be of AC 23 duty as per IS: 4064-1978 as amended up to date. They shall be complete with suitable HRC cartridge type fuses.
- (v) Switch boards shall house starters for motors with independent current sensing type single phase prevent or for each starter.
- (vi) Volt meter with selector switch, a set of indicating lamps and fuses for voltmeter and lamps shall be provided. Ammeter with CTs, and selector switch shall be provided with each motor starter. Instruments shall be flush mounted with the panel and have a class index not higher than 1.0. The instruments and accessories shall be provided whether or not specifically indicated in the tender specifications.
- (vii) The fabrication of switchboard shall be taken up only after the drawings for the fabrication of the same are approved by the Engineer-in-charge.
- (viii) Switchboards shall be fabricated as per specifications indicated in sub-para above.
- (ix) The layout shall be designed for convenient connections and inter-connections with the various switchgear. Connections from individual compartments to cable alleys shall be such as not to shutdown healthy circuits in the event of maintenance work becoming necessary on a defective circuit.
- (x) Care shall be taken to provide adequate clearances between phase bus bars as well as between phase bus bars, neutral and earth.
- (xi) Where terminations are done on the bus bars by drilling holes therein, extra cross section shall be provided for the bus bars. Alternatively, terminations may be made by clamping.
- (xii) Provision shall be made for proper termination of cables at the switchboards such that there is no strain either on the cables, or on the terminators. Cables connected to the upper tiers shall be duly clamped within the switchboard.
- (xiii) Identification labels shall be provided against each switchgear and starter compartment, using plastic/aluminum engraved labels.
- (xiv) Metallic danger board conforming to relevant IS shall be fixed on each electrical switchboard.

10.7 SYSTEM CONTROLLER

For controlling operation of pumps as per Para 2.4.1.14 and indicating fault, system controller shall be provided. The system controller shall consist of relays, timer, contactors etc. and shall be designed to operate the fire pumps with interlocking and fault indication as described in Para 2.4.1.15. Annunciation window shall be provided to indicate following faults:

- (i) Low water level in UG tank
- (ii) Low water level in terrace tank.
- (iii) Main pump failed to start.

- (iv) Main pump failed during operation.
- (v) Diesel pump failed to start.
- (vi) Diesel pump failed during operation
- (vii) Supply to Main Pump failed
- (viii) Supply to Pressurization Pump failed
- (ix) Supply to Terrace Pump failed.

Suitable sensors, differential pressure switches, monitors shall be provided at respective locations. The control system shall be operational on 12 Volt/24 Volt DC starting batteries of engine. Battery chargers shall be provided to ensure that the batteries remain charged. Batteries shall be sealed maintenance free type.

10.8 REMOTE INDICATING PANEL

- (i) The remote indicating panel shall be provided in the fire control room. This panel shall have necessary status indication of all electric motors.
- (ii) Back indication to show the status of operation of all the motors, pressure in the system, water level in underground and overhead tank etc. shall be provided.
- (iii) Panel shall be fabricated from not less than 1.6 mm thick CRCA sheet and powder coated after 7 tank treatment process. The panel shall be dust, damp and vermin proof. This shall be of wall mounting type. This shall be complete with necessary termination arrangements, multicore cables, tag blocks, control transformer, designation plastic labels, double earth stud etc. as required.

10.9 POWER CABLING

- (i) Unless otherwise specified, the power cables shall be XLPE insulated, PVC outer sheathed aluminum conductor, armoured cables 1100 V grade. The power cables shall be of 2 core for single phase, 4 core for sizes up to and including 25 sq.mm for 3 phase and 3-1/2 core for sizes higher than 25sq.mm for 3phase. Alternatively, XLPE/PVC insulated copper cable (single core/multicore armoured/unarmoured) of grade 1100 V shall be used.

For main power cable(s) from LT Room to Fire Pumps Panel, if the cable(s) is taken in cable trench duly filled with sand & with proper distancing from other cables within the cable trench, or in fire rated shaft, then the cable(s) of above type be used. However, if the cable(s) is likely to be exposed to fire, then fire survival cable(s) shall be used.

- (ii) Power cables shall be of sizes to meet the starting and running current of motors fed and shall be as approved by the Engineer-in-Charge, after taking into consideration the load, the length of cabling.
- (iii) Cables shall be laid in suitable metallic trays suspended from ceiling, or mounted on walls. Cable ducts shall not be provided in pump rooms. Cable trays shall be of perforated steel sheet with adequate structural strength and rigidity. Necessary supports and suspenders for cable trays shall be provided by the contractor as required.

10.10 CONTROL WIRING

- (i) Control wiring shall be done using ISI marked PVC insulated and PVC sheathed, 2.5 sq.mm, 250 V grade, armoured multi-core copper conductor cable. The control cable shall also be laid in the same manner as power cable.
- (ii) The number and size of the control cables shall be such as to suit the control system design adopted by the contractor.
- (iii) Runs of control wires within the-switchboard shall be neatly bunched and suitably

supported/clamped. Means shall be provided for easy identification of the control wires.

- (iv) Control wiring shall correspond to the circuitry/sequence of operations and interlocks approved by Engineer-in-Charge.

10.11 EARTHING

- (i) Provision of earth electrodes and the type of earthing shall be as specified in the tender specifications.
- (ii) The earth work shall be carried out in conformity with CPWD Specifications for Electrical works (Part-I), Internal 2013.
- (iii) Metallic body of all motors, medium voltage equipment and switch boards shall be connected by two separate and distinct earth conductors to the earth stations of the installations. Looping of such body earth conductors is acceptable from one equipment, or switch board to another.
- (iv) The size of earth conductors for body earthing of equipment shall be 2 Nos. 6 mm dia copper wire/2 Nos. 25 x 3 mm G.I. strip
- (v) Armoring of cables shall be connected to the body of the equipment/switch board at both the ends. Compression type glands shall be used for all such terminations in the case of PVC/ XLPE cables.

10.12 PAINTING

All panels shall be supplied with the manufacturer's standard finish painting or as indicated in the Schedule of Work.

11. INSTALLATION, TESTING AND COMMISSIONING

11.1 SCOPE

This chapter covers the requirement of Installation, testing and commissioning of firefighting system.

11.2 PREPARATION AND APPROVAL OF DRAWING

On award of the work, the contractor has to prepare working drawings as per Para 1.17.2 and submit to the Engineer-in-charge for approval. The work is to be executed as per approved drawings. The stage of approval of drawings is therefore very important. All drawings should be carefully and critically examined before approval. The requirements of various components of firefighting system have been described in previous chapters dealing with the components. However, generally following points are to be taken care while examining and approving the drawings.

11.2.1 Site survey should be carried out in detail.

11.2.2 In addition to building plans, layout plan along with landscape plan/horticulture plan and other services plans should be consulted while deciding route of underground pipes from pump house and around the building.

11.2.3 As far as possible, underground pipe are not to be laid under road, pavement, building and long open spaces. The locations along road, foot path in earth may be preferred.

- 11.2.4** The location of yard hydrants, fire service inlet and fire service connection are to be decided based on consideration of Para 2.4.1.8 to Para 2.4.1.10. However necessary adjustments are to be made so that these components do not become hindrance in vehicular movement and entrance to the building. Requirement of other building services are also to be given due consideration. Symmetry should be maintained for aesthetic considerations.
- 11.2.5** Pipe sizes are to be decided in accordance with provision of Para 2.4.1.2 and 4.5.4.
- 11.2.6 Pump House:-**The layout of equipment in pump house is very important from operation and maintenance considerations. The requirement of pumps and engine have been described in Chapter 5 and 6. In case other equipment i.e.

water supply pumps etc. are to be installed in the same pump house, sufficient space shall be left for them as well. The dimensioned foundation drawing of pumps should be available for marking in the pump room layout. The layout is to be prepared in such a way that it should be possible to maintain any equipment without disturbing the adjoining equipment. Electrical panels are to be installed at a location which is easily accessible near the entrance to the pump house and there should be no possibility of water dripping over or near the electrical panel. Typical layout of fire pump house is shown in Figure -10.

11.2.7 Terrace Pumps:- The location of pumps and terrace pipe may be decided keeping in view location of terrace tanks for firefighting and other services. The pipe line should not cause undue hindrance for movement of maintenance personnel at the terrace.

11.2.8 Electrical Panel :- Complete wiring drawing, layout etc. are to be examined to ensure that provisions of agreement are incorporated in the drawing. Sizes of various panel and mounting arrangement may be decided keeping in view ease of operation and aesthetic consideration as well.

11.3 INSTALLATION:-

The requirements of installation of various components have been described in previous chapters. However, following precautions are to be taken during execution of the work.

11.3.1 The pump and motor/engine are to be perfectly aligned on the base plate so that there is no vibration during operation. All nuts, bolts, washers shall be of adequate size and galvanized.

11.3.2 The pipe supports should be decided in a way that the weight of pipes and valves are not transferred to the pumps and supports do not cause hindrance in movement inside the pump house. As far as possible, floor supports may be provided in pump house.

11.3.3 All valves shall be installed at a height and in a position that their operation by right hand is conveniently possible.

11.3.4 All pressure gauges should be installed so that the dial is vertical and is visible while entering the pump house.

11.3.5 Electrical panels should not be installed at floor level. The panels shall be sufficiently raised above ground level. If panels are to be mounted on wall, an angle iron frame shall be provided so that at least 75 mm space is left behind the panels. The panels shall be easily approachable.

11.3.6 Cable trays are to be used for laying of power and control cable inside pump house. No cable is to be laid at floor level/in trench. Cable tray layout should give neat appearance. All cable tray shall be adequately supported from the ceiling/floor.

11.3.7 Drain pump shall be installed in the sump provided as per Para 3.2.2 (viii). The pump shall operate automatically for which water level sensor shall be provided.

- 11.3.8** In no case any structural member i.e. RCC wall, column, beam and floor are to be damaged during installation. Mechanical fasteners are to be used for grouting support. U.G. tank wall is not to be used for any support. No pipe/cable is to cross the pump house below ground level. Openings above ground level are only to be used for this purpose.
- 11.3.9** The engine installation work shall be carried out in accordance with the requirement of engine manufacturer and be got approved by the manufacturer or their authorized service center. The exhaust pipe should be suitably extended outside the pump house so that smoke does not effect nearby structure. Fuel tank shall be properly supported and located in a way that the same does not cause hindrance in movement in the pump house.
- 11.3.10** While excavating for laying of external pipes, suitable sign board/ barricading shall be provided to ensure that no person falls in the trench.
- 11.3.11** The width and depth of trench shall be adequate for laying the pipe 1m below ground level.
- 11.3.12** No earth or any other matter is to be allowed to enter the pipes. The ends shall be kept closed always.
- 11.3.13** The anticorrosive treatment is to be applied on the entire length laid underground in accordance with Para 7.5. The treatment is not to be damaged.
- 11.3.14** Pressure testing is to be carried out in sections before filling the earth back in the trench.
- 11.3.15** The earth filling is to be done in layers of 20 cm each and properly rammed so as to avoid possibility of settlement. Surplus earth/ malba shall be removed from the site by the contractor.
- 11.3.16** Where pipes crossing road likely to have heavy traffic, additional protection over pipe shall be provided to ensure that pipe is not damaged. However, semi-circular RCC Pipes shall be provided over cast iron pipes at road crossings.
- 11.3.17** External hydrants and fire service connection/ inlet shall be located parallel to the nearby road/ foot path so as to give proper appearance. Foundation shall be raised from below ground level and shall be properly plastered in plumb. The hydrants shall be facing the road/ approach. There shall be no obstruction in approaching the hydrants for operation.
- 11.3.18** Risers shall be parallel to the wall and in plumb. Adequate supports shall be provided from the wall. Opening around the pipe in slab shall be filled with CC and finished with plaster.
- 11.3.19** Internal hydrant shall be provided in the center and facing outside for ease of operation. Sufficient space shall be provided around the handle for operation. There shall be no

hindrance in moving the first aid hose reel.

- 11.3.20** Terrace pipes shall be supported on CC pedestals of adequate height. The pipe route shall be such as no hindrance is created in movement at the terrace. Pipes shall be sufficiently raised above terrace. It is to be ensured that water proofing is not damaged during laying of pipes.

11.4 TESTING

11.4.1 Initial Testing

- 11.4.1.1 During laying of pipes, the same shall be subjected to 10 kgf/cm² hydraulic pressure for a period of 24 hours, in sections.
- 11.4.1.2 After completion of the work, all valves/ fittings shall be installed in position and entire system shall be tested for 24 hours at a pressure of 10 kgf/ cm². The drop of pressure up to 0.5 kgf/cm² shall be accepted.

11.4.2 Final Testing

- 11.4.2.1 After completion, all operation checks as per Para 2.4.1.14 shall be carried out for automatic operation of the systems. For this purpose, landing valves may be opened at different locations. The exercise shall be repeated couple of times to ensure trouble free operation of the system.
- 11.4.2.2 **Flow Test:** - The design flow of pumps shall be checked. The pump shall be operated after opening a number of landing valves at different locations. Design pressure is to be maintained in the pump house. Water discharge is to be measured by drop in level in UG tank for a certain period. All pumps shall be tested one by one. The flow rate shall be not less than as specified while maintaining the design pressure in pump house.

11.5 INSPECTION BY LOCAL FIRE OFFICER

After completion of the work and testing to the entire satisfaction of Engineer-in- Charge, the installation shall be offered for inspection by Chief Fire Officer or his representative. Testing as desired by the Fire Officer shall be carried out. The contractor will extend all help including manpower during testing. The observations of Chief Fire Officer shall be part of the agreement. These shall be attended by the contractor. Nothing extra shall be paid for testing as above.

11.6 COMMISSIONING

- 11.6.1 Flushing the System:** Before commissioning, the entire system shall be flushed to ensure that any earth/ foreign matters which might have entered during installation are taken out. For this, pump may be operated and valves opened at different locations.
- 11.6.2** As soon as the work is complete, the system shall be commissioned and made available for use. Requirement of firefighting installations is equally important during occupation of the building. If the building is to be occupied in part, firefighting system of building completed shall be commissioned by isolating the system of under construction portion of the building.
- 11.6.3** The firefighting system shall be maintained and manned from the very first day of its commissioning.

11.6.4 Any defects noticed during the warranty period shall be promptly attended by the contractor and availability of the system at all time is to be ensured.

TERMINOLOGY

For the purpose of these Specifications, the following definitions shall apply:

1. **Air Release Valve:** A device by which the trapped air inside a riser main is expelled by water as the system is being charged.
2. **Air Vessel:** A cylindrical vessel installed in the wet-riser system at the bottom and top levels to counteract the water hammer effects.
3. **Authority concerned:** An Organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving or accepting equipment, materials, an installation, or a procedure.
4. **Automatic Fire Detection and Alarm System:** A system comprising components and sub-systems required for automatically detecting smoke, heat or fire, initiating an alarm and other actions as appropriate. This system also includes manually operated electronic fire alarm (MOEFA) system.

Note- MOEFA System (with or without automatic fire detection and alarm system) includes all or some of the components such as manual call stations (initiating an alarm for fire and other actions as required), talk-back system and public address system.

5. **Automatic Sprinkler System:** A system of water pipes fitted with sprinkler heads at suitable intervals and heights, and designed to actuate automatically, control or extinguish a fire by the discharge of water.
6. **Building, height of:** The vertical distance measured in the case of flat roofs, from the average level of the ground around and contiguous to the building or as decided by the Authority to the terrace of the last liveable floor of the building adjacent to the external wall; and in the case of pitched roofs, up to the point where the external surface of the outer wall intersects the finished surface of the sloping roof; and in the case of gables facing the road, the mid-point between the eaves level and the ridge. Where the building is located in a sloped terrain, height shall be determined from the lowest level (that is approachable by the fire service vehicles) to the terrace level. Architectural features serving no other function except that of decorations, shall be excluded for the purpose of measuring heights.
7. **Down-Comer:** An arrangement for firefighting within the building by means of down-comer pipe connected to terrace tank through terrace pump, gate valve and non-return valve and having mains not less than 100 mm internal diameter with landing valves on each floor/landing. It is also fitted with inlet connections at ground level for charging with water by pumping from fire service appliances and air release valve at roof level to release trapped air inside.
8. **Dry Riser:** An arrangement of firefighting within the building by means of vertical rising mains not less than 100 mm internal diameter with landing valves on each floor/landing which is normally dry but is capable of being charged with water usually by pumping from fire service appliances.
9. **Fire Compartment:** A space within a building that is enclosed by fire barrier or fire resistant walls on all sides, including the top and bottom.
10. **Fire Pump:** An electric/diesel pump installed at static water tank to charge the wet riser systems.
11. **Fire Resistance Rating:** The time that a material or construction will withstand the standard fire exposure as determined by the fire test done in accordance with the standard methods of fire tests of materials/structures as per the accepted standard.
12. **Fire Service Connections:** This is a 4-way collecting breeching with blank caps (without non-return valve) fixed to a 150 mm diameter pipe which is connected to the fire tank for filling from external source:

13. **Fire Service Inlet:** A 2- or 3-way collecting head with non-return valves fitted to the down comer/wet riser main, so that in case of need, fire service can directly pressurize the system with their pump.
14. **Foot Valve:** A valve fixed in the suction strainer of the fire pump which opens only inwards to allow in-rush of water into the pump suction and fire pump when the fire pump is actuated automatically/manually.
15. **High Rise Building:** A Building 15 m or above in height (irrespective of its occupancy).
16. **Hose Reel:** Firefighting equipment, consisting of a length of tubing fitted with a shut-off nozzle and connected to a reel, with a permanent connection to a pressurized water supply.
17. **Jockey Pump:** A pump of small capacity which is set to come into operation, automatically with drop in static pressure in the system and to automatically stop when the pre-set pressure is attained.
18. **Landing valve:** An assembly comprising valve(s) and outlet(s) connection from a riser system.
19. **Priming Tank:** A small tank erected in/over the pump house above the firefighting pumps to keep the pump casing and suction of the fire pump permanently flooded.
20. **Pressure Switch:** A switch connected on delivery line of fire pump or in the body of hydro-pneumatic tank at pre-set pressure level so designed to automatically start the fire pump or jockey pump, as the case may be, when the pressure in the system falls below the pre-set level.
21. **Pump Panel:** Panel comprising starting, stopping and indicating devices of fire pumps.
22. **Stand-by Pump:** A pump of same capacity as fire pump, driven by a diesel engine or connected to any other alternate source of electric supply.
23. **Static Water Tank:** Underground or surface water tank, constructed to store water for firefighting purpose.
24. **Terrace Pump:** An electricity driven pump, located on the terrace connected to a terrace tank with gate valve on suction side and to the internal hydrant system with non-return valve on delivery side.
25. **Terrace Tank:** A concrete/masonry/plastic steel tank constructed or erected on terrace of building for firefighting purpose.
26. **Wet-Riser:** An arrangement for firefighting within the building by means of vertical rising mains of not less than 100 mm internal nominal diameter with landing valves on each floor/landing for firefighting purposes and permanently charged with water from a pressurized supply.
27. **Wet-Riser-cum-Down Comer:** An arrangement for fire fighting within the building by means of vertical rising mains of not less than 100 mm. internal diameter with landing valves on each floor/landing connected to terrace tank for firefighting purpose, through a terrace pump, gate valve and non-return valve near the tank and to a fire pump, gate and non-return valves, over the static tank.

C.1 INTRODUCTION

This appendix cover suggestive guidelines for maintenance and operation of the Wet Riser System.

C.1.1 OBJECTIVE:-

- (i) To keep the entire system fully operational and functional at all times.
- (ii) In case full system cannot be kept functional for unavoidable reason, as much as possible, the installation shall be retained functional by isolating the defective section.

C.2 MAINTENANCE REQUIREMENT OF SYSTEM COMPONENTS

For maintaining firefighting system following points are to be taken care of:-

- C.2.1** To ensure availability of water in UG tank and terrace tank all the time and to maintain the tanks in clean condition.
- C.2.2** To ensure that the piping system is free from leakage. Any portion found to be leaking is to be isolated, rectified and connected with healthy system in shortest possible time.
- C.2.3** To ensure that all pumps are in good running condition. Any pump found to be defective is to be isolated by closing valves and attended immediately and put in to service in minimum time.
All pump glands shall be maintained in efficient working condition and the packing renewed as required to maintain the efficiency.
All working parts shall be kept clean and lightly oiled. Any necessary repairs shall be put in hand and carried out immediately.
- C.2.4** To ensure availability of power for electrical pumps, working of starters, switch gear and other electrical components.
- C.2.5** To ensure healthiness of diesel engine starting system, battery voltage, battery charger and availability of adequate diesel for engine operation.
- C.2.6** To check all landing valves of internal and external hydrants, isolating valves and replace the defective ones whenever necessary
- C.2.7** To check automatic operation of entire system by opening landing valves at different locations.
- C.2.8** To conduct fire drill at regular interval.

C.3 PERIODICAL TESTING

For achieving the objectives of Para C.1.1 and meeting the requirement of Para C.2 periodical testing and checking the system is essential. Various activities and their duration have been tabulated in Table C.1.

C.4 PROCEDURE

- C.4.1** Though the firefighting system operation is automatic, however for daily checking and attending to the system in case of operation, a trained pump operator shall be available round the clock.
- C.4.2** Operation and Maintenance instructions shall be available in the pump room and fire control room.

- C.4.3** Water for firefighting purpose is not to be used for any other purpose. However in order to avoid stagnation, the same shall be changed / cleaned regularly.
- C.4.4** Maintaining Diesel Engine is very important for the system operation since during fire, power supply is deliberately or un-deliberately switched off. Annual Maintenance Contract (AMC) of engine shall be given to the authorized service center of engine manufacturer. Adequate diesel should either be available in the pump house or nearby so that operation is not discontinued for want of diesel.
- C.4.5** Hydrant Mains / Ring Mains shall be tested once a fortnight with a pump delivering at its maximum pressure. A running test with two or more hose lines each 30m long operating shall be carried out.
- C.4.6** If any out let is found to be defective and replacement is not easily available the whole assembly should be removed and be replaced by blank off plate so that the system remains operational.
- C.4.7** Hose reels shall be subjected to regular inspection to ensure that all valve are functional, out let nozzle not choked. At least once in a year the same shall be subjected to operation to ensure that hose reel is in good condition and that the coupling joints are water tight. Flow should also be checked for the leakage of hose reel.
- C.4.8** All hydrants shall be examined systematically once a week to ensure that valves and spring catches are maintained in good condition.
Spare washers shall be kept for hydrant valve seats.
- C.4.9** Cut-off valves shall be thoroughly overhauled annually to remove sludge and other foreign matter collected in the valve seating.
- C.4.10** All isolating valves shall be checked for operation. The valves in closed position be opened and closed couple of times and the valves in open position be closed and opened couple of times so that when required, the valves perform their function.
- C.4.11** All hose boxes/hose stations shall be inspected externally once every week to ensure that the equipment installed therein is intact. Further, the hose boxes/hose stations shall be cleaned internally and externally once a month.
When the hose gets worn out at the tail end of the coupling(s), it is permissible to cut the end(s) of the hose. However should the lengths of the hose after cutting(s) fall below 90 percent of its original, the hose shall be discarded.

A hose register shall be kept showing Information such as date purchased, date brought into use, date cut (if reduced in length), is useful. Any hose becoming inefficient through use, neglect or from any other cause, shall be discarded.

Fire protection hose shall not be used for purposes other than fire protection and drill.

Hose pipes and their couplings shall be checked to ensure there is no

leakage during their use. The female coupling cam tooth mechanism be operated and lubricated for ensuring ease of operation.

C.4.12 Power supply to the pump house is not to be discontinued for any reason. Alternative arrangement shall be made in case any feeding switch gear is under repair / replacement.

C.4.13 It has to be ensured that there are no obstructions in front of the hydrants impeding accessibility

C.5 FIRE DRILL

For making the users familiar with the system, Fire Drills shall be conducted for high rise buildings, in accordance with the fire safety plan, at least once every three months for buildings during the first two years. Thereafter, fire drills shall be conducted at least once every six months.

All occupants of the building shall participate in the fire drill. However, occupants of the building, other than building service employees are not required to leave the floor or use the exits during the drill.

A written record of such drill shall be kept on the premises for a three years period and shall be readily available for fire brigade inspection.

For other buildings, fire drill shall be carried out once in six months.

Local fire service and nodal officer-in-charge of various parts of the building shall be involved in conducting fire drill. Operation of the system shall be demonstrated so that all users are confident of the system and aware of their duties and responsibilities during fire.

For further details, Annexure D- Guidelines for fire drill and evacuation procedures for high rise buildings of *Vol-1, Part-4 of NBC 2016 may be referred.*

TABLE C.1

PERIODICAL TESTING AND MAINTENANCE CHART

S. No.	System Component	Activity	Duration
1.	Water Tanks	(i) Level Check	Daily
		(ii) Cleaning	Once in a year
2.	Pumps	(i) Running	Daily (for min. 5 minutes)
		(ii) Test flow	Annually
		(iii) Lubrication	Quarterly
		iv) Gland packing check	Weekly
		<i>Electrically Driven Pumps:</i>	
		i) Bearing grease cup	Weekly
3.	Engine	(i) Running	Daily (for 5 minutes)

		(ii) Lubrication	Quarterly
		(iii) Battery Status	Weekly
		(iv) Fuel Tank check	Daily
		(v) Servicing	As per engine manufacturer's recommendations.
4.	Motor	(i) Running	Daily
		(ii) Starter contact checking	Weekly
		(iii) Insulation Resistance	Half yearly
5.	Hydrant Mains / Ring Mains	i) Testing	Fortnightly
6.	Piping	(i) Pressure	Daily
		(ii) Flushing	once in a year
7.	Hydrants	examination	Weekly
8.	Valves (Landing, Cut -off and Isolation)	(i) operation and oiling if necessary	Monthly
		(ii) Overhauling of all Cut- off valves	Annually
9.	Valves (Suction and Delivery)	(i) Examination	Half yearly
10.	Electrical Panels and Control System	(i) Operation	Monthly
		(ii) Connection and system components	Quarterly
11.	Hose boxes	i) External Inspection	Weekly
		ii) Internal and External cleaning	Monthly
12.	Hose Reel and Hose Pipes	(i) Physical check	Monthly
		(ii) Operation check	Annually
		(iii) Replacement	Depending upon physical condition.
13.	Fire Brigade Connections/ Inlet	(i) Physical check	Monthly.
		(ii) Operation check	Annually
14.	Instantaneous Coupling	(i) Physical check	Monthly.
		(ii) Lubrication	Once in Six months.
15.	Painting	(i) Out Door	Once in a year.
		(ii) In Door	Once in two years.

APPENDIX-D

MAINTENANCE OF AUTOMATIC SPRINKLER SYSTEM

- D.1 Maintenance of other firefighting installation has been described in Appendix- 'C' which hold good for sprinkler installations also. In addition following points shall be taken care.
- D.1.1 Sprinkler shall not be re-conditioned or repaired. Used and/or defective sprinklers shall be replaced by new ones.
- D.1.2 Sprinklers shall not be painted after installation.
- D.1.3 Spare Sprinklers - A stock of spare sprinklers shall be kept in Fire Control Room so that prompt replacement is possible after operation/damage of a sprinkler head. A minimum of 5% of the installed capacity or 25 sprinklers of all types whichever is more shall be kept in stock. Spanners for sprinklers and Teflon tape shall also be kept along with spare sprinklers in readiness.
- D.1.4 As far as possible, the installation shall be maintained in operating condition by blanking off pipe work feeding the inoperative part or parts where work is taking place.
- D.1.5 The inoperative part, if defective shall be attended to and connected with the operative system.
- D.1.6 *Action following sprinkler operation*
- D.1.6.1 Following the operation of sprinklers, the operated head shall be replaced with new ones and water supply shall be restored.
- D.1.6.2 The sprinklers in the vicinity of the operated sprinklers shall also be checked for damage by heat or any other cause and replaced if necessary.
- D.1.6.3 The sprinkler pump shall not be shut off until complete extinguishment of the fire. The starting of the pump shall be automatic but the stopping of the pump after an extinguishment shall be manual.
- D.1.7 All piping shall be examined to determine its conditions at least once a year.
- D.1.8 All Installation Control Valves and associated equipment shall be serviced and tested annually.
- D.1.9 Discharge test of sprinklers shall be carried out at least once in six months.
- D.1.10 Manual testing of the system shall be carried out once in six months.
- D.1.11 When normally opened valves are closed following system operation or test, suitable procedure shall be instituted to ensure that they are re-opened.
- D.1.12 The entire system shall be flushed at least once in a year.
- D.1.13 The sprinkler bulbs shall be kept free from paint or dust.

D.2 MAINTENANCE GUIDELINES

Following guidelines shall be followed for sprinkler maintenance.

- D.2.1 Maintenance and testing shall be carried out in a planned and systematic manner and records kept.
- D.2.2 Only trained personnel shall be engaged in the work. Contract with qualified agency for service, test and operation is recommended.
- D.2.3 Other firefighting installations are operated manually i.e. to operate a first aid hose reel or internal/external hydrant a person is required. As such during fire, when the system is in operation, somebody in the building is aware of it. In case of sprinkler operation, no one will come to know. For looking after sprinkler installation following personnel shall be available at all hours.
 - (a) A trained pump operator shall be available in the pump room.
 - (b) Depending upon the size of installations at least two or more trained personnel shall be available in fire control room.

LIST OF RELEVANT INDIAN STANDARDS


S. No	IS No.	Title
1)	IS-8757	Glossary of terms associated with Fire safety
2)	IS-884	Specification for first-aid hose reel for firefighting
3)	IS-901	Specification for couplings, double male and double female instantaneous pattern for firefighting,
4)	IS-902	Specification (for suction hose couplings for firefighting Purposes (third revision)
5)	IS-903	Specification for fire hose delivery couplings, branch pipe, nozzles and nozzle spanner. (fourth revision)
6)	IS-904	Specification for two and three- way suction collecting heads for firefighting purposes.
7)	IS-907	Specification for suction strainers, cylindrical type for firefighting purpose. (second revision)
8)	IS-908	Specification for fire hydrant, stand post type. (second revision)
9)	IS-909	Specification for underground fire hydrant. Sluice valve Type
10)	IS-636	Specification for Non percolating flexible firefighting delivery hose.
11)	IS-7637	Glossary of terms for firefighting equipment.
12)	IS-937	Specification for washers for water fittings for firefighting purposes.
13)	IS-1641	Code of practice for fire safety of buildings (general):General Principles for fire grading and classification.
14)	IS-1642	Code of practice for fire safety of buildings (General) : Details of construction. (second revision)
15)	IS-1643	Code of practice for fire safety of buildings (general) 'Exposure hazard. (first revision)
16)	IS-1644	Code of practice for fire safety of buildings (general):Exit requirements and personal hazard. (second revision)
17)	IS-1646	Code of practice for fire safety of buildings(general): Electrical installations. (third revision)
18)	IS-2871	Specification for branch pipe, universal for firefighting purposes.
19)	IS-2930	Functional requirements for hose laying tender for fire brigade use.
20)	IS-5290	Specification for landing valves.
21)	IS-8090	Specification for couplings, branch pipe, nozzle, used in hose reel tubing for firefighting.
22)	IS-8442	Specification for stand post type water and foam monitor for firefighting (first revision)
23)	IS-9972	Specification for automatic sprinkler heads. (first revision)
24)	IS-11101	Specification for extended branch pipe for fire brigade use
25)	IS -12349	Fire protection Safety sign.

26)	IS -12407	Graphic symbols for fire protection plan.
27)	IS -9668	Code of practice for provision and maintenance of watersupplies and firefighting.
28)	IS -3844	Code of practice for installation and maintenance of internal fire hydrants and hose reel on premises.
29)	IS -12585	Specification for thermoplastic house (Textile Reinforced) for Water General purpose.
30)	IS -10221	Code of practice for coating and wrapping of underground mild steel pipe lines. (first revision)
31)	IS-15105	Design and installation of fixed automatic sprinkler fire extinguisher system-Code of Practice.
32)	IS -325	Three phase induction motors.
33)	IS-1822	AC Motor starter for voltage not exceeding 1000 volts.
34)	IS -3624	Pressure and vacuum gauges.
35)	IS-1520	Horizontal centrifugal pumps for clear, cold, fresh water.
36)	IS-1239	Mild steel tubes, tubulars and other wrought steel fittings.
37)	IS -3589	Specification for Steel pipes for water, and sewage
38)	IS -6392	Steel pipe flanges.
39)	IS -778	Specification for copper alloy gate, globe and check valves and water works purpose (fourth revision)
40)	IS -2592	Recommendation for methods of measurement or fluid flow by means of orifice plates and nozzles.
41)	IS -732	Code practice for electrical wiring installations.
42)	IS 900	Code of practice for installation and maintenance of induction motors.
43)	IS -1248	Direct acting electrical indicating analogue electrical Measures and their accessories general requirement instruments.
44)	IS-2516	A. C. Circuit breakers for voltages not exceeding 1000 volts.
45)	IS -4047	Heavy duty air break switches and composite units of air break switches and fuses (for voltage not exceeding 1000 volts.
46)	IS -2208	HRC cartridge fuse links up to 650 volts.
47)	IS -1554 (Part I)	PVC insulated (heavy duty) electric cables for working voltage up to and including 1100 volts.
48)	IS:1536	Specification for Centrifugally Cast (Spun) Iron pressure pipes for water, gas & sewage (first revision)
49)	IS 1537	Specification for Vertically Cast Iron pressure pipes for water, gas & sewage (first revision)
50)	IS:1538	Specification for Cast Iron Fittings for pressure pipes for water, gas & sewage (third revision)
51)	IS:780	Sluice valve for water works purposes (50 to 300 mm size)
52)	IS:13095	Butterfly valves for general purpose.
53)	IS:13039	Code of practice for provision and maintenance of External Hydrant System (first revision)

IS : 6392 - 1971

TABLE 17 PLATE FLANGES FOR WELDING


(Clauses 4.1 and 5.1)


Nominal Pressure 1.6N/mm² All
dimensions in millimeters


* These dimensions are not to scale

Nominal Size	Pipe outer diameter $d_1\phi$	Flange		Raised Face		Boltin g	Drilli ng		
		$D\phi$	b	$d_4\phi$	f		No.	$d_2\phi$	$K\phi$
10	17.2	90	14	40	2	M12	4	14	60
15	21.3	95	14	45	2	M12	4	14	65
20	26.9	105	16	58	2	M12	4	14	75
25	33.7	115	16	68	2	M12	4	14	85
32	42.4	140	16	78	2	M16	4	18	100
40	48.3	150	16	88	3	M16	4	18	110
50	60.3	165	18	102	3	M16	4	18	125
65	76.1	185	18	122	3	M16	4	18	145
80	88.9	200	20	138	3	M16	8	18	160
100	114.3	220	20	158	3	M16	8	18	180
125	139.7	250	22	188	3	M16	8	18	210
150	168.3	285	22	212	3	M20	8	22	240
175	193.7	315	24	242	3	M20	8	22	270
200	219.1	340	24	268	3	M20	12	22	295
250	273	405	26	320	3	M24	12	26	355
300	323.9	460	28	378	4	M24	12	26	410

35 0	355. 6	520	32	438	4	M2 4	16	26	470
40 0	406. 4	580	36	490	4	M2 7	16	30	525
50 0	508	715	44	610	4	M3 0	20	33	650
60 0	609. 6	840	52	725	5	M3 3	20	36	770
70 0	711. 2	910	58	795	5	M3 3	24	36	840
80 0	812. 8	1025	64	900	5	M3 6	24	39	950
90 0	914. 4	1125	72	1000	5	M3 6	28	39	1050
1000	1016	1255	78	1115	5	M3 9	28	42	1170
1200	122 0	1485	94	1330	5	M4 5	32	48	1390








ELEVATIONAL VIEW


LEGEND

- F-1 ELECTRICAL FIRE PUMP
- F-2 DIESEL DRIVEN FIRE PUMP
- F-3 JOCKEY PUMP
- PV PRESSURE VESSEL
- FH FIRE HYDRANT
- VALVE
- FLEXIBLE CONNECTION
- NON-RETURN VALVE
- SPRINKLER



TYPICAL SYSTEM OF PUMPING WITH ONE ELECTRIC, ONE DIESEL FIRE PUMP


FIG.3




ELEVATIONAL VIEW

LEGEND


- F-1 DIESEL DRIVEN FIRE PUMP
- F-2 EL. HYDRANT FIRE PUMP
- F-3 JOCKEY PUMP
- F-4 EL. SPRINKLER PUMP
- PV PRESSURE VESSEL
- FH FIRE HYDRANT
- FAP FIRE ALARM PANEL
- SP SPRINKLER
- VALVE
- FLEXIBLE CONNECTION
- NON-RETURN VALVE
- SPRINKLER



TYPICAL SYSTEM OF PUMPING WITH TWO ELECTRIC, ONE DIESEL FIRE PUMP
FIG.4




- | | | | |
|--------------------------------------|---------------------------|-----------------------------|---------------------------------|
| SP - SPRINKLER PUMP | HOSE REEL | SPRINKLER HEAD | FIRE BRIGADE DRAW FROM TANK |
| DP - DIESEL PUMP | SINGLE HEAD LANDING VALVE | CABLE TO ANNUNCIATION PANEL | MANUAL CALL BOX |
| JP - JOCKEY PUMP | AIR RELEASE VALVE | CABLE CONDUIT | FIRE BRIGADE INLET TANK FILLING |
| HP - HYDRANT PUMP/MAIN ELECTRIC PUMP | AIR CUSHION TANK | HOOTER | FLOW SWITCH |
| SH - SUCTION HEAD | SLUICE VALVE | NON-RETURN VALVE | |
| R - PIPE TO RISER | | | |
| Y - PIPE TO YARD HYDRANT | | | |
| S - PIPE TO SPRINKLER SYSTEM | | | |
| AV - AIR VESSEL | | | |
| ICV - INSTALLATION CONTROL VALVE | | | |




TYPICAL ARRANGEMENT OF WET RISER AND TOTAL SPRINKLER SYSTEM OF BUILDING

FIG. 6




**TYPICAL ARRANGEMENT FOR PROVIDING COMBINED FIRE
FIGHTING AND DOMESTIC WATER STORAGE TANK**


Fig. 7



WET RISER SHAFT DOOR DETAILS



WET RISER SHAFT
Fig. 8




CLEVIS HANGERS

Heavy duty
clevis hangers with
pendulum movement
to adjust varying heights



SPRINKLER HANGERS



PIPE SUPPORT SPLIT CLAMP

split pipe support
clamps for vertical,
horizontal &
roof hanging
installation




FULL THREADED RODS

in sizes
8 mm
10 mm
12 mm




TYPICAL PIPE SUPPORT

Fig. 9




TYPICAL LAYOUT OF SPRINKLER INSTALLATION

Fig. 11



(a) Two end side with central feed



(b) Three end side with end feed

(c) Two end centre with end feed

(d) Three end centre with central feed

TYPICAL LAOUT OF CONNECTION OF SPRINKLERS

List of Approved Makes		
S. No.	Item	Manufacturer's Name
	FIREFIGHTINGSYSTEM	
1	ELECTRIC DRIVEN MOTOR AND PUMPS	GRUNDFOS/MATHERPLATT/EBARA/WILO/EMU/DP/KIRLOSKAR
2	ELECTRIC DRIVEN MOTOR AND PUMPS(INDIANSTANDARD)	GRUNDFOS/MATHERPLATT/EBARA/WILO/EMU/DP/KIRLOSKAR
3	DIESELENGINE	KIRLOSKAR/ASHOKLEYLAND/CUMMINS
4	G.I.ANDM.S.PIPES	TATA/JINDALHISAR/PRAKASH
5	FIRE HOSE PIPES/RR.L. HOSE PIPE	NEWAGE/CRC/PADMINI/G.TECH/INDIAN RAYON./SUPEREME/KARTAR/ATASEE
6	FIRSTAID FIRE HOSE REELWITH BRACKET,DRUM AND NOZZLE	JYOTI/TIGER/PADMINI/NEWAGE/KARTAR/ATASEE
7	G.I.ANDM.S.FITTINGS	R/KS/UNIK/DRP/ZOLOTO
8	C.I.DOUBLE FLANGED SLUICE/GATE VALVE/NON-RETURN VALVES	H.SARKAR/KIRLOSKAR/SANT/LEADER/KALPANA/KARTAR/ZOLOTO
9	SLIM SEAL BUTTERFLY VALVES (PN-1.6)	AUDCO/SANT/C&R/KSB/INTERVALVE/CASTLE/ARROW/KARTAR/ZOLOTO
10	C.I.BODYBUTTERFLYVALVE	AUDCO/SANT/INTERVALVE/CASTLE/ARROW/DANFOSS/KARTAR/ZOLOTO
11	GUN METAL BODY BUTTERFLY VALVE	AUDCO/SANT/INTERVALVE/CASTLE/ARROW/DANFOSS/KARTAR/ZOLOTO
12	ALARMGONG	HDOREQUIVALENT
13	QB.SPRINKLER	TYCO/GRINNEL/KIDDE/CENTRAL/GTECH/ATASEE
14	WRAPPING AND COATING	PYPECOAT/RUSTECH/COALTEK
15	FABRICATED FIRE HOSE CABINET	STEELAGE/NEWAGE/G.TECH/ATASEE
16	BRANCH PIPE/ NOZZLES (GUNMETAL/BRASS/COPPER&BRA	MINMAX/NEWAGE/G.TECH/ATASEE

	SS /ALUMINIUM)	
17	FIRE EXTINGUISHERS	MINIMAX/NEWAGE/G.TECH/ATASEE
18	FIRE BRIGADE CONNECTION	NEWAGE/MINIMAX/G.TECH/SUPEREX/ATASEE
19	SUCTION STRAINER	JATPEE/GRANDPRIT/DASHMESH/KARTAR/ZOLOTO
20	VIBRATION ELIMINATOR CONNECTORS	RESISTOFLEX/KHANWAL/D.WREN
21	SINGLE PHASING PREVENTOR (CURRENTOPERATED)	L&T/SIEMENS/MINILEC
22	FLOWMETER	SCINTIFICEQUIPMENT.(P)LTD.SHALIBANDAHYDRABAD-500263/
23	ELECTRICAL SWITCHGEAR & STARTERS	SIEMENS/L&T/ABB
24	CABLES	SKYTONE/GLOSTER/NICCO/ASIAN/(RPG)UNIVERSAL/ POLYCAB/PLAZA
25	FLOW SWITCH	POTTER/SYSTEMSENSOR/JHONSONCONTROL
26	MAIN CONTROL PANEL (POWDER COATED)	TRICOLITE/ADLEC/TRINITRON/VIDYUTCONTORL/CONELEC /ENGINEERING(P)LTD./UNILECLTD./RISHA/ ADVANCEPANNEL/ADVANCEGEARS/EQUIVALENT
27	PRESSURE SWITCHES	INDFOSS/SWITZER
28	PRESSURE GAUGE	H.GURU/FIEBIG
29	BATTERY	EXIDE/PRESTOLITE
30	PAINT ENAMEL OF PIPES ETC.	J&N/ASIAN/NEROLAC/BERGER
31	ANNUNCIATION PANEL FOR SPRINKLER SYSTEM	PCD/SAFEWAY/AGNI(INDIA)/AGNI
32	ALARM VALVE & HYDRAULIC ALARM MOTOR WITH COVERING	MATHER&PLATT/HD
33	CONTACTOR	L&T/SIEMENS/SCHNEIDE/GE/ABB
34	THIMBLES / FERRULES (TINNED COPPER)	DOWELOREQUIVALENT
35	CABLEGLANDS	COMMEX/POWER/GRIPWELL
36	POWERCAPACITOR	L&T/CROMPTON/ASIAN/DUCATTI

37	MEASURING METER (DIGITAL)	L&T/SIEMENS/AE/ENERCON
38	DASH FASTENER	HILTI/FISHER
39	PAINT PRIMERS	ASIAN/JENSONNICHOLSON
40	WELDING ELECTRODES	ADVANI/ESAB/VICTOR
41	PIPE HANGERS	CHILLY/GMGR
42	MCB, DBs	MDS/LEGRAND/INDOASIAN(GOLDLINE)HEGER

****The recommended makes are listed. In case of any other competitive makes/reputed makes, the bidder may submit the same with compliance statement to technical specifications & parameters at the time of pre bid meeting only for final approval from HAFED.**

The Successful Bidder after work award should take approval in written from HAFED for equipment brand& technical specifications before procurement.

Section 7
Bill of Quantities

CPC & DRY WAREHOUSE Fire Fighting Indicative BoQ for HAFED MFP						
S.No.	DSR no	Description	Unit	Quantity	Rate (INR)	Amount (INR)
	DSR_AOR_2019	FIRE FIGHTING SYSTEM				
1	1	Fire Pumps and Accessories				
		Supplying, installation, testing and commissioning of Electric driven Main Fire Pump suitable for automatic operation and consisting of following, complete in all respects, as required :				
	a)	Horizontal type, multistage, centrifugal, split casing pump of cast iron body & bronze impeller with stainless steel shaft, mechanical seal conforming to IS 1520.				
	b)	Suitable HP Squirrel cage induction motor, TEFC, synchronous speed 1500 RPM, suitable for operation on 415 volts, 3 phase 50 Hz, AC supply with IP 55 protection for enclosure, horizontal foot mounted type with Class-'F' insulation, conforming to IS-325.				
	c)	M.S. fabricated Common base plate, coupling, coupling guard, foundation bolts etc. as required.				
	d)	Suitable cement concrete foundation duly plastered with anti vibration pads.				
	1.1	2850 lpm at 88 m Head	Set	2	440000	8,80,000.00

		<i>Note: Contractor shall include in his rates for providing pressure switches, pressure guages, wiring, cabling from pressure switch to panel etc. complete as required to operate the system automatic/manual. Pump shall be protected against running dry.</i>				
2	DSR _AOR 2019 / 2	Supplying, Installation, Testing and Commissioning of diesel engine driven main fire pumping set complete in all respect as required suitable for automatic operation and consisting of following:				
		Horizontal type, multistage, centrifugal pump of cast of iron body and bronze impeller with stainless steel shaft, mechanical seal conforming to IS 1520.				
		Suitable HP, 1500 RPM water cooled with radiator, diesel engine conforming to relevant IS standard complete with auto starting mechanism, 12 /24 volts electric starting equipment, diesel tank, exhaust pipe extended upto 10 m outside pump house duly insulated with 50 mm thick glass wool with 1.0 mm thick aluminium sheet cladding, residential silencer, instruments and protection as per standard specification, stop solenoid for auto stop in the event of fault with audio indications, painted with post office red colour etc. as required.				
		M.S fabricated, common base plate, coupling, coupling guard, foundation bolts etc. as required				

		Suitable cement concrete foundation duly plastered and with anti vibration pads.				
	2.1	2850 lpm at 88 m Head	Set	1	683155	6,83,155.00
		<i>Note: Contractor shall include in his rates for providing pressure switches, pressure guages, wiring, cabling from pressure switch to panel etc. complete as required to operate the system automatic/manual. Pump shall be protected against running dry.</i>				
3	DSR AOR 2019 / 3	Supplying, installation, testing and commissioning of electric driven pressurisation pump suitable for automatic operation and consisting of following, complete in all respects, as required : (Jockey Pump)				
		Horizontal type, multistage, centrifugal pump of cast iron body and bronze impeller with stainless steel shaft, mechanical seal conforming to IS : 1520.				
		Suitable HP squirell cage induction motor TEFC type suitable for operation on 415 volts, 3 phase 50 Hz AC supply with IP 55 class of protection for enclosure, horizontal foot mounted type with Class-'F' insulation, conforming to IS : 325.				
		M.S.fabricated Common base plate, coupling, coupling guard, foundation bolts etc. as required.				
		Suitable cement concrete foundation duly plastered and with anti vibration pads.				
	3.4	300 lpm at 88 m Head	Set	2	165976	3,31,952.00

		<i>Note: Contractor shall include in his rates for providing pressure switches, pressure guages, wiring, cabling from pressure switch to panel etc. complete as required to operate the system automatic/manual. Pump shall be protected against running dry.</i>				
4	DSR _AOR 2019 / 4	Supplying, installation, testing and commissioning of electric driven terrace pump suitable for automatic operation and consisting of following, complete in all respects, as required: (Terrace Pump)				
	a)	Horizontal type, multistage, centrifugal, split casing pump of cast iron body & bronze impeller with stainless steel shaft, mechanical confirming to IS : 1520				
	b)	Suitable HP squirrel cage induction motor TEFC type suitable for operation on 415 volts, 3 phase, 50 Hz, AC supply with IP55 class of protection for enclosure, horizontal foot mounted type with Class-'F' insulation, conforming to IS-325.				
	c)	M.S.fabricated common base plate, coupling, coupling guard, foundation bolts etc.as required.				
	d)	Suitable cement concrete foundation duly plastered and with anti vibration pads.				
4.1		900 lpm at 35 m Head	Set	1	100946	1,00,946.00

		<i>Note: Contractor shall include in his rates for providing pressure switches, pressure guages, wiring, cabling from pressure switch to panel etc. complete as required to operate the system automatic/manual. Pump shall be protected against running dry.</i>				
7		Fabrication, Supplying, Installation, Testing and Commissioning of electrical control panel of cubical construction, floor mounted type, fabricated out of 2mm. Thick CRCA sheet, compartmentalized with hinged lockable doors, dust and vermin proof, powder coated of approved shade after 7 tank treatment process, cable alley, inter-connection, having switchgears and accessories mounting and internal wiring, earth terminals, numbering etc. complete in all respect, suitable for operation on 415 V, 3 phase, 50 Hz. AC supply with enclosure protection class IP 42 as required.				
		COMMON PANEL IN FIRE PUMP HOUSE				
	5.6	INCOMER				
		800 Amps. 50KA TP & N 4P MCCB ICS=100%				
		Voltmeter (0-500 Volts) with selector switch.				
		Ammeter (0-800 Amps.) with selector switch and CT's etc.				
		Set of 3 Phase indicating lamp.				
		Set of AI bus bar 1000 Amps.				
		OUTGOING				
		Main Fire Pump				

		250 Amps. MCCB with suitable HP fully automatic star/delta starter with over load protection, current sensing type single phase prevent or complete with all accessories and internal wiring required for automatic operation, selector switch for local/remote, auto/manual/Off operation. (Hydrant & Sprinkler pump)				
		Jockey Pump				
		125 Amps. MCB with suitable HP fully automatic star/delta starter with over load protection, current sensing type single phase prevent or complete with all accessories and internal wiring required for automatic operation, selector switch for local/remote, auto/manual/Off operation.				
		Diesel Engine Control.				
		Control for Diesel Engine comprising:				
		Auto/Manual selector switch & 3 attempt starting device, timers and relays as required, push buttons, start/stop in manual mode.				
		Indication lamp for High/Low Lub. Oil pressure, High Water Temp and Engine ON indication.				
		Battery charger suitable for 12 V/24 V DC with boost and trickle selector switch, 0-30 V DC volt meter, 0-20 Amp DC Ammeter.				
		All standard relays and accessories for automatic operation of diesel engine.				

		Designing, Supply, Installation, Testing and commissioning of system controller to control operation of main electric fire pump, diesel pump, Pressurization pump, Terrace pump in sequence as per specification consisting of relays, timers. Sensors, annunciation window for fault indication, complete as per specification	Set	1	575711	5,75,711.00
7	DSR_AOR_2019/22	Providing and fixing Pressure Switch in the MS pipe Line including connection etc. as required.	Each	8	1508	12,064.00
8	DSR_AOR_2019/14	Providing, installation, testing and commissioning of dual plate non-return valve of following sizes confirming to IS: 5312 complete with rubber gasket, GI bolts, nuts, washers etc. as required.				
a	14.1	300 mm dia.	Each	R/O	60243	
b	14.8	200 mm dia	Each	2	29075	58,150.00
c	14.7	150 mm dia.	Each	4	17577	70,308.00
d	14.5	100 mm dia	Each	6	10836	65,016.00
e	14.4	80 mm dia	Each	R/O	7539	
9	DSR_AOR_2019/15	Providing, installation, testing and commissioning of stainless steel Y-strainer fabricated out of 1.6 mm. thick stainless steel sheet with 3 mm. dia holes with stainless steel flange.				
a	15.5	250 mm dia	Each	4	36394	1,45,576.00
b	15.4	200 mm dia.	Each	6	22052	1,32,312.00
c	15.3	150 mm dia.	Each	6	10659	63,954.00
d	15.2	100 mm dia	Each	4	6450	25,800.00

e	15.1	80 mm dia.	Each	R/O	4573	
10	DSR_ AOR_ 2019/ 11	Providing, Fixing , testing and commissioning of butterfly valve of rating PN 1.6 with bronze/gunmetal seat duly ISI marked complete with nuts, bolts, washers, gaskets, conforming to I.S:13095 of following sizes as required.				
a	11.8	250mm dia (gear operated)	Each	4	20163	80,652.00
b	11.7	200mm dia	Each	8	14958	1,19,664.00
c	11.6	150mm dia	Each	4	8699	34,796.00
d	11.5	100mm dia	Each	6	6454	38,724.00
e	11.4	80mm dia	Each	4	4842	19,368.00
11		SPRINKLER SYSTEM				
	DSR_ AOR_ 2019/ 7	Providing, laying, testing & commissioning of ' C' class heavy duty MS Pipe conforming to IS 3589 and 1239 including fittings like elbows, tees, flanges, tapers, nuts bolts, gaskets etc., fixing the pipe on the wall/ceiling with suitable clamps and painting with two or more coats of synthetic enamel paint over one or two coat of primer of required shade complete as required. (For Sprinkler system)				
		200mm dia				
a	7.8	150 mm dia	RM	100	2064	2,06,400.00
b	7.7	100 mm dia	RM	500	1499	7,49,500.00
c	7.6	80 mm dia	RM	100	1122	1,12,200.00
d	7.5	65 mm dia	RM	100	1004	1,00,400.00
e	7.4	50 mm dia	RM	100	787	78,700.00
f	7.3	40 mm dia	RM	100	651	65,100.00
g	7.2	32 mm dia	RM	300	527	1,58,100.00
h	7.1	25 mm dia	RM	3650	471	17,19,150.00

12	DSR_ AOR_ 2019/ 21	Providing fixing testing and commissioning of 15 mm size quartzoid bulb type sprinklers , of rating 68 degree C. pendent with required accessories				
a	21.1	Pendent Sprinkler	Each	2204	484	10,66,736.00
13		Providing, fixing, testing and commissioning of butterfly valve PN 1.6 with Bronze/SS seat duly ISI marked complete with Nuts, Bolts, Washers, Gaskets, conforming to IS 13095, of following sizes as required.				
a	11.5	100 mm dia	Each	24	6454	1,54,896.00
b	11.6	150mm dia	Each	6	8699	52,194.00
14	DSR_ AOR_ 2019/ 23	Providing & fixing flow switch in following sizes M.S. pipe including connection etc as required				
	23.1	100 mm Dia	Each	12	7362	88,344.00
	23.2	150 mm. Dia	Each	6	8869	53,214.00
16	DSR_ AOR_ 2019/ 24	Providing and fixing, testing and commissioning of installation control valve of Cast iron body and brass/bronze working parts comprising of water motor alarm, bronze seat clapper and clapper arm, hydraulically driven mechanical gong bell to sound continuous alarm when the Sprinkler system activates, pressure gauges, emergency releases, strainer, pressure switch cock valve complete with drain valve and bypass, test control box, ball valves, MS pipe of required size, flanges, orifice plate, gasket etc. of size as required.				
a	24.3	150 mm dia	Each	6	47898	2,87,388.00

17	DSR_ AOR_ 2019/ 19	Supplying and fixing of fire brigade connection of cast iron body with gun metal male instantaneous inlet couplings complete with cap and chain as reqd. For suitable dia MS pipe connection conforming to IS 904 as required :				
a	19.3	3 way - 150 mm dia M.S. Pipe	Each	6	9302	55,812.00
		HYDRANT SYSTEM				
18	DSR_ AOR_ 2019/ 6	Providing laying, testing & commissioning of 'C' class heavy duty MS Pipe conforming to IS 1239/3589 i/c fittings like elbows, tees, flanges, tapers, nuts bolts, gaskets etc. in ground including welding, excavation & providing cement concrete blocks as supports, anticorrosive treatment with coaltar/asphalt tape as per IS 10221, refilling the trench etc. of following sizes complete as required.				
a	6.1	200 mm. dia (wall thickness = 6.3 mm)	RM	30	3169	95,070.00
b	6.2	150 mm dia	RM	850	2376	20,19,600.00
19	DSR_ AOR_ 2019/ 10	Supplying and fixing Single headed external yard hydrant valve with 1 No. 63 mm dia instantaneous FM Gunmetal/Stainless Steel coupling and cast iron wheel, ISI marked, conforming to IS 5290 (type A) with blank Gunmetal/Stainless Steel cap and chain as required :				
	10.2	Single headed Stainless steel	Each	16	5987	95,792.00
20	DSR_ AOR_ 2019/ 9	Supplying and fixing single headed internal hydrant valve with instantaneous unmetal/Stainless Steel coupling of 63 mm dia with cast iron wheel ISI marked conforming to IS 5290 (Type -A) with blank Gunmetal/Stainless Steel cap and chain as required :				
	9.2	Single headed Stainless steel	Each	28	5987	1,67,636.00

25	DSR_ AOR_ 2019/ 11	Providing, Fixing , testing and commissioning of butterfly valve of rating PN 1.6 with bronze/gunmetal seat duly ISI marked complete with nuts, bolts, washers, gaskets, conforming to I.S:13095 of following sizes as required.				
a	11.7	200 mm dia	Each	2	14958	29,916.00
b	11.6	150 mm dia	Each	8	8699	69,592.00
c	11.5	100 mm dia	Each	2	6454	12,908.00
d	11.4	80 mm dia	Each	44	4842	2,13,048.00
26	DSR_ AOR_ 2019/ 16	Supplying and fixing 63 mm dia, 15 mtr. long RRL hose pipe with 63 mm dia Male and Female SS couplings duly binded with GI wire, rivets etc. coforming to IS 636 (type-A) as required.				
	16.1	Gun Metal	Each	106	5188	5,49,928.00
30	DSR_ AOR_ 2019/ 13	Supplying and fixing orifice plate made out of 6 mm thick stainless steel (Grade 304) with orifice of required size to be fitted between flange & landing valve of external and internal hydrants to reduce pressure at the outlet to the level of 3.5 kg/cm2 complete as required.	Each	28	1291	36,148.00
		DETECTION SYSTEM & FIRE EXTINGUISHERS				
		CONDUIT				
35	DSR_(E&M) _2018 _1201	Supply and laying of 20 SWG MS conduit painted with 2 coats of primer and two coats of red enamel paint, embedded in slab/run on wall/wall chases/on false ceiling etc., with pull wires and necessary conduit accessories.	Rmt	3800	43	1,63,400.00

		OVERHEAD FIRE TANK				
44	HSR/ 30.119	Providing and fixing HDPE WATER STORAGE TANKS of Sintex, Diplast, O.K. Supreme make with covers/lids marked with IS:12701 on roof top of buildings including cost of hoisting and placing in position, making connections with inlet and outlet pipes, providing overflow and scour provisions with suitable plug on scour pipe including cost of nipples, washers, flanges for connections in tanks complete in all respects to the satisfaction of Engineer-in-Charge. 5000 ltr. Capacity	Each	6	25908.00	1,55,448.00
		UNDERGROUND FIRE TANK & PUMP ROOM				

45	DSR PAR 2021	Planning, Designing and construction of RCC underground water storage tank and underground pump room for pumps as above, including MH cover & Frame for cleaning, desilting and glass bricks wherever required in the slab for lighting arrangement and inlet/outlet and overflow and special (sluice valves, NRV, Scour, outlet to pumps in pump room etc complete in all respect to the satisfaction of Engineer in charge. Pump room to be as per the requirements of local fire authority with staircase to go down and mumty with door and ventilation as required and contingent works complete in all respects for operation. The volume of pump room to be counted towards the total KL of the pumping stationand UGR. Final capacity to be as per FIre Department requirement	KL	500.00	20,000	1,00,00,000.00
		Total Amount				

Non- Scheduled items (Indicative BoQ) for Dry Warehouse & Core Processing Centre Building

Sr No		Description	UoM	Qty	Rate (to be filled by the bidders)	Amount
21	NS	80 mm dia. Stand post for hydrant valve	Each	44		
22	NS	Fixed Water Monitor of 63 mm size having nozzle bore of 32 mm	Each	9		
23	NS	100 mm dia. Stand post for Water Monitor	Each	9		
24	NS	Supply of hose cabinet of size 600 mm x 450mm x 300mm made of 3 mm thick powder coated aluminium sheet with 6 mm thick gazed glass doors including necessary locking arrangements suitable to accommodate external hydrant , 2 nos 15 m long hose pipe, 1 no branch pipe with 4 nos MS angle (40x40x8) supports grouted in floor and duly powder coated with post office red external and white internal paint complete in all respects for external hydrant as required	Each	53		